


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County <b>Haskell</b>	Fraction <b>Center of</b> 1/4 1/4 SE 1/4	Section number <b>18</b>	Township number T <b>27</b> S	Range number R <b>33</b> E <b>W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city: <b>18 S. &amp; 3/4 E. of Garden City.</b>			3. Owner of well: <b>Forrest Cox</b> R.R. or street: City, state, zip code: <b>Sublette, KS</b>		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>10-15-76</b> Well depth <b>450</b> ft.	
5. Type and color of material <b>See attachment</b>		From		To	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material <b>Steel</b> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36</b> lbs./ft. Dia. <b>16</b> in. to <b>450</b> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; Gauge No. <b>219</b>			
		10. Screen: Manufacturer's name <b>Brown</b> Type <b>Louvered</b> Dia. <b>16"</b> Slot/gauze <b>.080</b> Length <b>120'</b> Set between <b>350</b> ft. and <b>330</b> ft. <b>320</b> ft. and <b>220</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>1/4 x 1/8</b>			
		11. Static water level: <input type="checkbox"/> mo./day/yr. <b>136</b> ft. below land surface Date <b>10-18-76</b>			
		12. Pumping level below land surfaces: <b>180</b> ft. after <input type="checkbox"/> hrs. pumping <b>1451</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
		14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade			
		15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.			
16. Nearest source of possible contamination: <b>None observed</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: <b>Flat</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drlg. &amp; Supply 145</b> Business name License No. <input type="checkbox"/> Address <b>Box 639 Garden City, KS</b> Signed <b>E.L. Rothwell</b> Date <b>10-26-76</b> Authorized representative		

27-33E-18-1/4-1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 8-10-76  
 STREET ADDRESS Mrs. Edna Tapley TEST # 1 E. Log  
 CITY & STATE Sublette, KS DRILLER Martinez  
 COUNTY Haskell QUARTER SE SECTION 18 TOWNSHIP 27 RANGE 33

LOCATION Center of 1/4

%	DRILLED FOOTAGE			WELL LOCATION	
	From	Pay	To	Description of Strata	Static Water Level Proposed Well Depth
	0		3	Top soil	
	3		21	Brown clay	
	21		50	Sand fine to med.	
	50		141	Sand fine to med. coarse, small to large gravel	
30	141	19	160	Sand fine to med. coarse, small to large gravel, loose, used water, few clay st.	
40	160	18	178	Sand fine to med. coarse, small gravel, few large gravel, loose, used water, few clay st.	
	178		202	Brown sandy clay, lime rock	
30	202	28	230	Sand fine to med. coarse, small gravel, few med. gravel, loose, used water, few white rock st.	
40	230	11	241	Sand fine to med. coarse, small to med. gravel, loose, used water, few clay st.	
30	241	13	254	Sand fine to med. coarse, small to med. gravel, loose, used water, clay st.	
	254		260	Brown sandy clay	
	260		281	Blue sand, fine to med. coarse, small gravel	
	281		300	Blue and gray sand fine to med. coarse, small gravel, blue clay st.	
60	300	21	321	Gray sand fine to med. coarse, small to med. gravel, loose, used water, few white rock st.	
70	321	45	366	Sand fine to med. coarse, small to large gravel, few cemented st., used water, few white rock st.	
	366		405	Brown sandy clay, lime rock st.	
Fair	405	40	445	Brown sandy clay, brown rock st., sandstone st., used water, hard in places	
	445		460	Shale	
		195			
				TOTAL DEPTH OF WELL 450 FT.	
				Set up east	
				Dig pit on south	