

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County Haskell County	Fraction SW 1/4 NW 1/4 SE 1/4	Section number 25	Township number T 27 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: 1 1/2 West from the North side of Sublette, 12 North, 3/4 West, 1/2 North Street address of well location if in city:			3. Owner of well: Don Linberg R.R. or street: Box 7 B City, state, zip code: Leoti, KS 67861		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 26 in. Completion date 8-31-77 Well depth 430 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 430 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Johnson Type Johnson Calv. Dia. 100-16" Slot/gauze 0-300 Plain, 300-380 Perf. Set between 380-400 Screen 400-410 ft. Perf. 410 - 420 Screen 420-430 Perf. Gravel pack? yes Size range of material 1/2 to 5/8		
			11. Static water level: <input checked="" type="checkbox"/> mo./day/yr. 194 ft. below land surface Date 7-19-77		
			12. Pumping level below land surfaces: 218 ft. after 2 hrs. pumping 925 g.p.m. 221 ft. after 4 hrs. pumping 1150 g.p.m. Estimated maximum yield 1150 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 7 stg. 12" Bowl Model number <input type="checkbox"/> HP 200 Volts <input type="checkbox"/> Length of drop pipe 260 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed <i>[Signature]</i> Date 8-10-77 Authorized representative			

27
 33
 25
 Sec
 1/4
 MINTER-WILSON

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

DON LINBERG
HASKELL COUNTY
6-30-77

Location: SW 25-27-33

Static Water Level- 202'

Pivot

0	1	Top soil
1	24	Brown clay
24	50	Fine sand and clay
50	95	Brown clay
95	143	Med. to course gravel (Loose)
143	213	Fine to med. sand and gravel (Loose)
213	237	Brown clay
237	303	Blue clay
303	377	Fine to med. sand and gravel (Loose)
377	403	Fine to med. sand and gravel (Loose) (small hard streaks)
403	410	Brown sandy clay
410	429	Fine to med. sand and gravel small streaks of clay 15% (Loose)
429	446	Brown clay (Tight)
446	510	Brown sandy clay
510	537	Brown and gray clay (Tight)
537	545	Gray and yellow clay with brown rock (Hard)
		300 Plain
		80 Perf
		20 Screen
		10 perf
		10 Screen
		10 Perf
		<hr/> 430