

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Haskell</b>	Section <b>SE 1/4 SE 1/4 SW 1/4</b>	Section number <b>29</b>	Township number <b>T 27 S R 33</b>	Range number <b>33</b>																				
2. Distance and direction from nearest town or city: <b>Approximately 15 miles N of Sublette, Kansas</b> Street address of well location if in city:			3. Owner of well: <b>Russell Kells Feed Yard</b> R.R. or street: <b>Satanta, Kansas 67870</b> City, state, zip code:																						
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile			6. Bore hole dia. <del>17 1/2</del> in. Completion date <b>9/15/77</b> Well depth <b>571</b> ft.																						
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																						
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																						
5. Type and color of material			9. Casing: Material <b>Steel</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <b>5</b> PVC <input type="checkbox"/> Weight <b>11.35</b> lbs./ft. Dia. <b>8 7/8</b> in. to <b>571</b> ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.125</b>																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;">From</th> <th style="width:20%;">To</th> </tr> </thead> <tbody> <tr><td colspan="2"><b>See Attachment</b></td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> </tbody> </table>			From	To	<b>See Attachment</b>																		10. Screen: Manufacturer's name <b>Johnson</b> <b>Screen</b> Type <b>Continuous</b> Dia. <b>8 5/8"</b> Slot/gauze <b>7060</b> Length <b>60'</b> Set between <b>300</b> ft. and <b>320</b> ft. <b>340</b> ft. and <b>380</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>#1 Coarse</b>		
			From	To																					
			<b>See Attachment</b>																						
11. Static water level: <input type="checkbox"/> mo./day/yr. <b>226</b> ft. below land surface Date <b>9/21/77</b>																									
12. Pumping level below land surfaces: <b>Not pumped</b> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>150</b> g.p.m.																									
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																									
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> Inches above grade																									
15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.																									
16. Nearest source of possible contamination: ft. <b>200</b> Direction <b>East</b> Type <b>Feed Yard</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																									
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Red Jacket</b> Model number <b>12 MB</b> HP <b>15</b> Volts <b>440</b> Length of drop pipe <b>2 1/2</b> ft. capacity <b>100</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																									
(Use a second sheet if needed)																									
18. Elevation: <b>x Flat</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Sply 145</b> Business name License No. _____ Address <b>Bob 639, Garden City, Ks</b> Signed <b>Barry A. Richmond</b> Date <b>9/21/77</b> Authorized representative																						

T 27 S R 33  
 Sec 29 SE SE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

