

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County Haskell County	Fraction NW 1/4 SW 1/4	Section number 35	Township number T 27 S R 33 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 West from the North side of Sublette, 11 North, 1 1/2 West			Name of well: Don Linberg		
Street address of well location if in city:			R.R. or street: Box 7 B		
			City, state, zip code: Leoti, KS 67861		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 1-16-76 Well depth 535 ft.	
		<p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 535 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219</p>		10. Screen: Manufacturer's name Johnson	
				<p>Type Johnson Galv. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4 to 5/8</p>	
5. Type and color of material			From	To	11. Static water level: <input checked="" type="checkbox"/> 285 ft. below land surface Date 7-30-77 mo./day/yr.
<p>Casing Schedule</p> <p>0 - 300 Plain</p> <p>300 - 350 Perf.</p> <p>350 - 370 Screen</p> <p>370 - 400 Perf.</p> <p>400 - 410 Screen</p> <p>410 - 515 Perf.</p> <p>515 - 525 Screen</p> <p>525 - 535 Perf.</p>					12. Pumping level below land surfaces: 316 ft. after 2 hrs. pumping 625 g.p.m. 336 ft. after 4 hrs. pumping 1125 g.p.m. Estimated maximum yield 1125 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					<input checked="" type="checkbox"/> Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 8 atg. 12" Bowl Model number <input type="checkbox"/> HP 200 Volts <input type="checkbox"/> Length of drop pipe 360 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed <i>[Signature]</i> Date 10-77 Authorized representative
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

27 33 W 35 NUSE SW

Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON LINBERG
HASKELL COUNTY
12-11-76

Location: SW 35-27-33 from NE corner of $\frac{1}{2}$ 400 Ft.
south

Static Water Level- 200'

Test #6		
0	1	Top soil
1	37	Brown clay
37	103	fine sand and clay
103	130	Med. to coarse gravel Loose
130	230	Fine to med. sand and gravel Loose
236	260	Brown clay
260	337	Blue clay
337	350	Blue clay 50% gravel Tight
350	384	Fine to med. sand and gravel tight
384	395	Fine to med. sand and gravel Loose hard streak
395	401	Fine to med. sand and gravel Loose
401	410	Brown clay
410	446	Fine to med. sand and gravel 10% clay Loose
446	485	brown clay
485	523	Brown clay 30% fine to med. sand fine gravel Loose
523	554	Fine to med. sand and gravel with brown rock Loose
554	590	Brown and yellow clay sand shale Hard

T.D. ~~554~~ 535