


LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: Haskell	$\frac{1}{4}$ $\frac{1}{4}$ SE $\frac{1}{4}$	8	T 27 S	R 34 E/W
Distance and direction from nearest town or city? Garden City 17 South 10 1/2 West - 1/4 North on Pivot				
Street address of well if located within city?				
WATER WELL OWNER: Walter Kuhn Estate				
RR#, St. Address, Box #: % Tommy Lewis				
City, State, ZIP Code: Satanta, KS 67870				
Board of Agriculture, Division of Water Resources Application Number:				
DEPTH OF COMPLETED WELL: 456 ft. Bore Hole Diameter: 26 in. to 456 ft. and in. to ft.				
Well Water to be used as: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 11 Injection well 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well 12 Other (Specify below)				
Well's static water level: 146 ft. below land surface measured on April month 21 day 81 year				
Pump Test Data Est. Yield gpm: Well water was 172 ft. after 2 hours pumping 1320 gpm Well water was 189 ft. after 3 hours pumping 1520 gpm				
TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Casing Joints: Glued Clamped Welded X Threaded 2 PVC 4 ABS 7 Fiberglass				
Blank casing dia 16 in. to 456 ft. Dia in. to ft. Dia in. to ft. Dia in. to ft.				
Casing height above land surface 12 in., weight 36.4 lbs./ft. Wall thickness or gauge No. 219				
TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)				
Screen or Perforation Openings Are: 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)				
Screen-Perforation Dia 16 in. to 456 ft. Dia in. to ft. Dia in. to ft. Dia in. to ft.				
Screen-Perforated Intervals: xxxx Perf 240-260 xxxx Screen 260-280 ft. xxxx Perf 280-290 ft. xxxx Screen 290-300 ft. xxxx Perf 300-340 xxxx Screen 340-350 ft. xxxx Perf 350-430 ft. xxxx Screen 430-450 ft.				
Gravel Pack Intervals: From 10 ft. to 456 ft. From ft. to ft. From ft. to ft.				
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other				
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft. From ft. to ft.				
What is the nearest source of possible contamination: 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below) 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines Center of 1/4 Section N/A				
Direction from well: How many feet? Water Well Disinfected? Yes No X				
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year				
Pump Installed? Yes X No If Yes: Pump Manufacturer's name Goulds 6 Stage Model No. 12 JMC HP 125 Volts				
Depth of Pump Intake 300 ft. Pumps Capacity rated at 800 gal./min.				
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other				
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on April month 30 day 1981 year				
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208				
This Water Well Record was completed on May month 15 day 1981 year under the business name of Minter Wilson Drilling Co., Inc. by (signature) <i>M. Wilson</i>				
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:				
				
ELEVATION:				
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)				
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.				

OFFICE USE ONLY

T

87

R

34

PM

SEC

X

C
05
1/4

1/4

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

100,000 G.P.
and Over
and Rec.

Phone 276-8769 • P.O. Box A • GARDEN CITY, KANSAS 6784

January 8, 1981

**Tommy Lewis
Haskell County**

**Location: SE 8-27-34
Static Water Level - 180'
Test #**

Pivot

0	5	Top Soil
5	21	Fine Sand 10% Clay
21	34	Brown Sandy
34	60	Fine to Med. Sand and Gravel Loose
60	112	Med. Coarse Gravel Loose
112	143	Brown Clay
143	170	Brown Clay 25% Gravel
170	186	Brown Sandy Clay 35% Fine Sand Loose
186	192	Fine to Med. Sand and Gravel Loose
192	203	Brownish Yellow Clay
203	214	Blue Clay
214	236	Brown Sandy Clay 15% Gravel Loose
236	287	Fine to Med. Sand Gravel Streak of Med. Coarse Gravel Loose
287	289	Brown Sandy Clay
289	303	Fine to Med. Sand and Gravel Loose 10% Clay
303	309	Brown Clay
309	320	Fine to Med. Sand and Gravel Loose
320	342	Brown Sandy Clay
342	353	Fine to Med. Sand and Gravel Loose
353	367	Brown Sandy Clay Hard
367	428	Brown Clay White Rock
428	440	Fine to Med. Sand and Gravel Loose
440	453	Fine to Med. Sand and Gravel Streak of Med. Coarse Gravel Loose
453	465	Yellow Red and Shale Hard

T.D. 456