

LOCATION OF WATER WELL:		Fraction	Section Number		Township Number		Range Number	
County: <b>Haskell</b>		$\frac{1}{4}$ <b>E2</b> $\frac{1}{4}$ <b>SE</b> $\frac{1}{4}$	<b>9</b>		<b>T 27 S</b>		<b>R 34 E/W</b>	
Distance and direction from nearest town or city street address of well if located within city?								
<b>From Sublett 12 miles No. 9 miles West 4 1/2 miles nO. 1/2 mile West</b>								
2 WATER WELL OWNER: <b>Kearny Co. Feeders</b>								
RR#, St. Address, Box # : <b>Lakin, Ks.</b>								
City, State, ZIP Code : <b>67860</b>								
Board of Agriculture, Division of Water Resources								
Application Number:								
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:								
4 DEPTH OF COMPLETED WELL: <b>392</b> ft. ELEVATION:								
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.								
WELL'S STATIC WATER LEVEL <b>152</b> ft. below land surface measured on mo/day/yr <b>4-18-85</b>								
Pump test data: Well water was <b>173</b> ft. after hours pumping <b>1300</b> gpm								
Est. Yield <b>1550</b> gpm: Well water was <b>176</b> ft. after hours pumping <b>1550</b> gpm								
Bore Hole Diameter <b>30</b> in. to <b>392</b> ft., and in. to ft.								
WELL WATER TO BE USED AS:								
5 Public water supply 8 Air conditioning 11 Injection well								
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)								
<input checked="" type="radio"/> Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well								
Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, mo/day/yr sample was submitted								
Water Well Disinfected? Yes No <input checked="" type="checkbox"/>								
5 TYPE OF BLANK CASING USED:								
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped								
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded <input checked="" type="checkbox"/>								
7 Fiberglass Threaded.								
Blank casing diameter <b>16</b> in. to <b>260</b> ft., Dia in. to ft., Dia in. to ft.								
Casing height above land surface <b>12</b> in., weight <b>42.05</b> lbs./ft. Wall thickness or gauge No. <b>250</b>								
TYPE OF SCREEN OR PERFORATION MATERIAL:								
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)								
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)								
SCREEN OR PERFORATION OPENINGS ARE:								
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)								
2 Louvered shutter 4 Key punched 7 Torch cut 9 Drilled holes 10 Other (specify)								
SCREEN-PERFORATED INTERVALS: From <b>260</b> ft. to <b>392</b> ft., From ft. to ft.								
GRAVEL PACK INTERVALS: From <b>10</b> ft. to <b>392</b> ft., From ft. to ft.								
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other								
Grout Intervals: From <b>0</b> ft. to <b>10</b> ft., From ft. to ft., From ft. to ft.								
What is the nearest source of possible contamination:								
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well								
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well								
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)								
13 Insecticide storage <b>NA</b>								
Direction from well? How many feet?								
FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG								
Test log attached								
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="radio"/> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>4-30-85</b> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>208</b> This Water Well Record was completed on (mo/day/yr) <b>5-9-85</b> under the business name of <b>Minter Wilson Drilling Co.</b> by (signature) <b>L. H. Dassamau</b>								
INSTRUCTIONS: Use typewriter or ball point pen, PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Environmental Geology Section, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.								

*The Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Kearney Co. Feeders

Haskell Co.

6-6-84

Location: SE 9-27-34

1/2 mile West of test # 7

30' East of pivot

Static water level 185'

Test # 8

0	1	Top soil
1	38	Fine sand
38	50	Fine to medium sand & gravel (Loose)
50	155	Medium coarse gravel (Loose)
155	168	Brown sandy clay
168	205	Medium coarse gravel (Loose)
205	209	Brown sandy clay
209	230	Medium coarse gravel (Loose)
230	250	Brown sandy clay
250	287	Fine to medium sand & gravel, coarse streak of gravel (Loose)
287	299	Brown sandy clay
299	354	Fine to medium sand & gravel (Loose)
354	369	Brown sandy clay
369	387	Fine to medium sand & gravel
387	442	Brown, Yellow clay
442	450	Shale