


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Haskell</b>	Township name	Fraction <b>SW 1/4, NW 1/4, NE 1/4</b>	Section number <b>13</b>	Town number <b>T 27S</b>	Range number <b>R 34 W</b>
Distance and direction from nearest town or city: <b>17 1/2 N. of Satanta, Kansas</b> Street address of well location if in city:				3 Owner of well: <b>John Frey</b> Address: <b>Satanta, Kansas 67870</b>		
Locate with "X" in section below: N  W S E 1 Mile				Sketch map:		
2 Type and color of material				4 Well depth: <b>347</b> ft. Date of completion <b>4-21-75</b> Well diameter <b>26</b> in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material <b>Steel</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>347</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <b>16</b> in. to <b>347</b> ft. depth		
				8 Screen: Manufacturer <b>Brown</b> Type <b>Louvered</b> Dia. <b>16"</b> Slot/gauze <b>1/8</b> Length <b>110'</b> Set between <b>237</b> ft. and <b>347</b> ft. Fittings: <b>1/4 to 1/8</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
				9 Static water level: <b>148</b> ft. below land surface Date <b>4-21-75</b>		
				10 Pumping level below land surfaces: <b>161</b> ft. after <b>1325</b> hrs. pumping <b>1325</b> g.p.m. ft. after <b>1325</b> hrs. pumping <b>1325</b> g.p.m. Estimated maximum yield <b>1325</b> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.		
(use a second sheet if needed)				14 Nearest source of possible contamination <b>None Observed</b> ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation  Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply 145</b> Business name License No. Address <b>Box 639 Garden City, Ks.</b> Signed <b>James H. Henkle</b> Date <b>5/8/75</b> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

# DRILLERS TEST LOG

CUSTOMERS NAME	John Fray	DATE	2-18-75
STREET ADDRESS		TEST #	8 E. Log Hole
CITY & STATE	Satanta, Kansas	DRILLER	Lee
COUNTY	Haskell	QUARTER	NE
	SECTION	13	TOWNSHIP
		27	RANGE
			34

LOCATION Approx 700 Ft. Northwest of Test # 2

### WELL LOCATION

%	Drilled from	Pay	Footage to	Description of Strata	Static Water Level Proposed Well Depth
	0		12	Fine sandy soil	
	12		25	Sand fine med., few clay st. Few l	
	25		65	Brown clay, few sand st., few ledges.	
	65		75	Sand fine med. coarse, small gravel, clay st.	
	75		160	Sand fine med. coarse, small to med. gravel, to large, rough in places. Very few clay st. Used water. Some extra large gravel.	
75	160	31	191	Sand fine med. coarse, small to med. gravel. Few large. Very few clay st. Used water. Mud heavy	
	191		195	Brown clay	
60	195	11	206	Sand fine med. coarse, small to med. gravel. Vry few large. Some clay st. Used water.	
	206		211	Red sandy clay	
70	211	39	250	Sand fine, med. coarse, small to med. gravel. Some large. Very few clay st. Used some water. Few rough spots.	
	250		255	Brown clay ledges, sand st.	
40	255	8	263	Sand fine, med. some coarse, few clay st.	
	263		275	Brown clay and sand st.	
40	275	8	283	Sand fine, med. some clay st.	
	283		312	Brown clay and sand st.	
40	312	5	317	Fine sand, few med.	
	317		324	Sandy clay and sand	
35	324	6	330	Fine to med. sand, some clay	
	330		331	Brown clay	
60	331	9	340	Sand fine med. coarse, few, small gravel.	
	340		347	Brown clay and sand fine st. some med.	
	347		400	Brown clay and sand st.	
	400		440	Sandy clay, sand st. and limerock ledges.	

TOTAL DEPTH OF WELL	347 Ft.
---------------------	---------

Set up West; Pit on North.