

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 14	Township number T 27 S	Range number R 34 E/W
2. Distance and direction from nearest town or city: 16 mi. N and 7 mi. W of Sublette, Kansas			3. Owner of well: Manley Oliver R.R. or street: R. R. City, state, zip code: Satanta, Kansas		
4. Locate with "X" in section below: Sketch map: <p>Near center in NE 1/4, Sec. 14, T27S, R34W, Haskell County, Kansas.</p>			6. Bore hole dia. 28 in. Completion date 7/30/76 Well depth 336 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia 16 in. to 177 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Foster, Cook Type slot, ww Dia. 16" Slot/gauze 1/8" Length 159' Set between 177 ft. and 336 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 5.0mm		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 142 ft. below land surface Date 3/25/76		
			12. Pumping level below land surfaces: 148 ft. after 1 1/2 hrs. pumping 1016 g.p.m. 152 ft. after 1 hrs. pumping 2859 g.p.m. Estimated maximum yield 3500 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: unk. ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12 KM HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 220 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name License No. Address Garden City, Kansas Signed [Signature] Date 18 Nov 76 Authorized representative		
19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5