


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 17	Township number T 27 S	Range number R 34 E/W
X Distance and direction from nearest town or city: 1 1/2 North, 4 West of Satanta, Ks.			3. Owner of well: Melvin Tunis Box 79 City, state, zip code: Satanta, Kansas 67870		
4. Locate with "X" in section below:			6. Bore hole dia. 9 7/8 in. Completion date 10-28-76 Well depth 422 ft.		
Sketch map: 			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil			9. Casing: Material PVC Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 4 lbs./ft. Dia. 6 in. to 422 ft. depth Wall thickness: inches or Dia. 6 in. to 422 ft. depth gage No. 316		
			10. Screen: Manufacturer's name Jess & Lowell Type PVC Dia. 6" Slot/gauze 1/8" Length 100' Set between 202 ft. and 422 ft. 302 ft. and 422 ft. Gravel pack? yes Size range of material 3/16"		
			11. Static water level: 172 ft. below land surface Date 10/21/76		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 40 - 50 g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless unit unit ____ inches above grade		
			15. Well grouted? yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction north Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Manufacturer's name Aermotor Model number SD19 HP 3 Volts 220 Length of drop pipe 252 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 687864 Signed [Signature] Date 10/2/76 Authorized representative		
19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5