

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name Center	Fraction of NE $\frac{1}{4}$	Section number 20	Town number T 27 S	Range number R 34 W
Distance and direction from nearest town or city: 12 3/4 N. & 10 1/4 W. of Sublette Street address of well location if in city:				3 Owner of well: Melvin Tunis Address: 2011 N. 6th Garden City, Ks. 67846		
Locate with "X" in section below: N W E S 1 Mile				4 Well depth: 416 ft. Date of completion 3-5-75 Well diameter 26 in.		
2 Type and color of material SEE ATTACHMENT				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material Steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 36 lbs./ft. 16 in. to 416 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Manufacturer Johnson Type Continuous Dia. Slot/gauze 150 Length 30' Set between 266 ft. and 276 ft. Fittings: 326' & 336', 366' & 376' Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4" to 1/8"		
				9 Static water level: 170 ft. below land surface Date 3-5-75		
				10 Pumping level below land surfaces: 200 ft. after hrs. pumping 1404 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: None Observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, Ks. Signed Richard J. Henkle Date 3/17/75 Authorized representative						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

# DRILLERS TEST LOG

CUSTOMERS NAME Melvin Tunis DATE 2-4-75  
 STREET ADDRESS 2011 North 6th TEST # 3 No E. Log  
 CITY & STATE Garden City, Kansas DRILLER Henderhan  
 COUNTY Haskell QUARTER NE SECTION 20 TOWNSHIP 27 RANGE 34

LOCATION 1320 Ft. West and 1320 Ft. North of the SE corner of the NE 1/4

## WELL LOCATION

%	DRILLED		FOOTAGE	Description of Strata	Static Water Level
	from	Pay			Proposed Well Depth
	0		2	Top soil	
	2		30	Brown clay, limerock ledges and fine sand st.	
	30		37	Fine sand and clay st.	
	37		67	Fine sand, very loose.	
	67		77	Brown sandy clay and fine sand st.	
	77		91	Sand and clay, mixed	
	91		105	Sand fine med. coarse, small gravel. Brown gravel.	
				Used water. Some clay st.	
80	105	165	270	Sand fine med. coarse, small, med. large gravel.	
				Brown gravel, cobblestones, very rough, Used water,	
				loose in places.	
75	270	50	320	Sand fine med. coarse, small med. large gravel. Brown	
				gravel, some cobblestone. Loose in places. Rough	
				in places. Hard ledges, few clay st.	
70	320	25	345	Sand fine med. coarse, small med. large gravel. Brown	
				gravel. Very hard ledges, few clay st.	
	345		352	Brown clay, limerock and sand st. Sticky in places.	
75	352	6	358	Sand fine med. coarse, small med. large gravel. Brown	
				gravel. Used water. Rough in places.	
	358		362	Brown clay	
70	362	27	389	Sand fine med. coarse, small med. some large gravel.	
				Brown gravel. Used water. Some clay st. Few hard	
				ledges.	
	389		401	Brown clay, limerock and sand, mixed. Loose at 394 ft.	
65	401	12	413	Sand fine med. coarse, some, small gravel. Used	
				water.	
	413		440	Brown sandy clay, limerock ledges, sticky places.	
		285			
				TOTAL DEPTH OF WELL 416 Ft.	
				Set up west; Dig pit on the north.	

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS  
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311  
 TEST HOLES\*\*\*\*\*STOCK WELLS\*\*\*\*\*IRRIGATION AND INDUSTRIAL WELLS\*\*\*\*\*