

1 LOCATION OF WATER WELL:		Fraction		Section Number		Township Number		Range Number	
County: <u>Haskell</u>		NE 1/4 SW 1/4 NE 1/4		21		T 27 S		R 34 EW	
Distance and direction from nearest town or city street address of well if located within city?									
From Hwy. 56-83 west of Sublette, 14 miles north, 9 miles west, 3,579 ft. north & 1,719 ft. west									
2 WATER WELL OWNER:		Danny Alexander RR#, St. Address, Box #: R R 1 - Box 77 City, State, ZIP Code: Satanta, Kansas 67870-9747							
		Board of Agriculture, Division of Water Resources Application Number: 15,093							
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: 455 ft. ELEVATION:							
		Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 250 ft. below land surface measured on mo/day/yr 3/25/98 Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter 30 in. to 455 ft. and in. to ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes.....No.....X; If yes, mo/day/yr sample was submitted							
		Water Well Disinfected? Yes No X							
		5 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded X 2 PVC 4 ABS 7 Fiberglass Threaded							
		Blank casing diameter 16 in. to 290 ft. Dia. in. to ft. Dia. in. to ft. Casing height above land surface 12 in. weight 42.05 lbs./ft. Wall thickness or gauge No. 250							
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement 8 RMP (SR) 11 Other (specify) 9 ABS 12 None used (open hole)							
SCREEN OR PERFORATION OPENINGS ARE:		5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)							
SCREEN-PERFORATED INTERVALS:		From 290 ft. to 455 ft. From ft. to ft. From ft. to ft. From ft. to ft. GRAVEL PACK INTERVALS: From 20 ft. to 215 ft. From 275 ft. to 455 ft. From ft. to ft. From ft. to ft.							
6 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout intervals: From 0 ft. to 20 ft. From 215 ft. to 275 ft. From ft. to ft.							
What is the nearest source of possible contamination:		10 Livestock pens 14 Abandoned water well 11 Fuel storage 15 Oil well/Gas well 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage N/A							
Direction from well?		How many feet?							
FROM	TO	LITHOLOGIC LOG				FROM	TO	PLUGGING INTERVALS	
		See attached log							
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 4/8/98 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 This Water Well Record was completed on (mo/day/yr) 4/14/98 under the business name of Minter-Wilson Drilling Co., Inc. by (signature) <i>Nora Keeler</i>									

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Danny Alexander
Haskell County
April 19, 1996

LOCATION NE $\frac{1}{4}$ 21-27-34 Hitch Church 1 West, 3/4 North,
 $\frac{1}{4}$ West to Pivot, 402' South, 81' West

Static Water Level - 270'

Test #1

0	1	Top soil	
1	12	Brown clay loose	01
12	35	Brown sandy clay	04
35	42	Fine sand	07
42	50	Brown clay	01
50	98	Fine sand	07
98	103	Brown sandy clay	04
103	112	Fine to medium sand	07
112	140	Coarse Gravel	15
140	233	Medium coarse gravel	14
233	257	Brown sandy clay	04
257	264	Fine to medium sand and gravel	17
264	272	Brown sandy clay	04
272	330	Fine to medium sand gravel	
330	335	Fine to medium sand and gravel hard pull down	17
335	374	Brown sandy clay 15% cemented sand stone	04
374	380	hard pull down 500	
380	420	Fine to medium sand	07
420	443	Brown sandy clay	
443	450	Brown sandy clay 10% sand stone	04
450	470	Yellow clay 10% sand stone	
470	470	Yellow clay 50% sand stone loose	01
470	472	Shale hard pull down 1200	19

RECEIVED

APR 20 1998

BUREAU OF WATER