


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 5	Township number T 27	Range number S R 35
2. Distance and direction from nearest town or city: from Standard Service station at Ulysses, Ks. 7 1/2 miles N.-11 E.-3/4 miles 3 1/2 N.			Owner of well: Charles Dew R.R. or street: RFD #1 City, state, zip code: Ulysses, Ks.			
4. Locate with "X" in section below: 			6. Bore hole dia. 9 3/4 in. Completion date 8/21/77 Well depth 350 ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Surface			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Very fine to fine sand			9. Casing: Material styrene Height: (Above or below) 18 in. Threading glued Surface 18 in. RMP PVC Weight 1.1 lbs./ft. Dia. 5 in. to 350 ft. depth Wall Thickness 3/32 inches or Dia. 5 in. to 350 ft. depth gage No. 320			
Fine to medium sand			10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 80' Set between 270 ft. and 350 ft. ft. and 1 1/4 ft.			
Medium to coarse sand & gravel w/clay breakers			11. Static water level: 168 ft. below land surface Date 8-18-77 mo./day/yr.			
Sand & gravel w/clay breakers			12. Pumping level below land surfaces: 170 ft. after 2 hrs. pumping 25 g.p.m. ft. after 4 hrs. pumping 40 g.p.m. Estimated maximum yield 40 g.p.m.			
Medium to coarse sand w/clay breakers			13. Water sample submitted: X Yes No Date 8-18-77 mo./day/yr.			
Sandy clay w/sand strips			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade			
Medium to coarse sand w/clay breakers			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.			
Sandy clay w/fine to medium sand			16. Nearest source of possible contamination: ft. 0 Direction SE Type SE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
(Use a second sheet if needed)			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Houck Bros. Drlg. Co. Model number 164 HP 1/4 Volts 115 Length of drop pipe 350 ft. capacity 40 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks: House under construction at the time the well was drilled		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. 67880 Address Box 487, Ulysses, Ks. Signed M. Beard Date 9/23/77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5