

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: <b>Grant</b>		$\frac{1}{4}$ $\frac{1}{4}$ <b>SE</b> $\frac{1}{4}$		<b>9</b>		<b>T 27 S</b>		<b>R 35 EW</b>					
Distance and direction from nearest town or city? <b>Ulysses 9 North - 12 East - 3/4 South - 1/2 West</b>					Street address of well if located within city?								
2 WATER WELL OWNER: <b>Galen Meyers</b>					Board of Agriculture, Division of Water Resources								
RR#, St. Address, Box # :					Application Number:								
City, State, ZIP Code :													
3 DEPTH OF COMPLETED WELL <b>485</b> ft. Bore Hole Diameter <b>26</b> in. to <b>485</b> ft. and in. to ft.													
Well Water to be used as:					5 Public water supply      8 Air conditioning      11 Injection well 1 Domestic      3 Feedlot      6 Oil field water supply      9 Dewatering      12 Other (Specify below) 2 Irrigation      4 Industrial      7 Lawn and garden only      10 Observation well								
Well's static water level ft. below land surface measured on <b>Pump setter, none test pumping</b> day year													
Pump Test Data					Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm								
4 TYPE OF BLANK CASING USED:					5 Wrought iron      8 Concrete tile      Casing Joints: Glued . . . . . Clamped . . . . . 1 Steel      3 RMP (SR)      6 Asbestos-Cement      9 Other (specify below)      Welded . . . . . <b>X</b> 2 PVC      4 ABS      7 Fiberglass      . . . . . Threaded. . . . .								
Blank casing dia <b>16</b> in. to <b>485</b> ft. Dia in. to ft. Dia in. to ft.													
Casing height above land surface <b>12</b> in., weight <b>36.4</b> lbs./ft. Wall thickness or gauge No. <b>.219</b>													
TYPE OF SCREEN OR PERFORATION MATERIAL:					7 PVC      10 Asbestos-cement 1 Steel      3 Stainless steel      5 Fiberglass      8 RMP (SR)      11 Other (specify) . . . . . 2 Brass      4 Galvanized steel      6 Concrete tile      9 ABS      12 None used (open hole)								
Screen or Perforation Openings Are:					5 Gauzed wrapped      8 Saw cut      11 None (open hole) 1 Continuous slot      3 Mill slot      6 Wire wrapped      9 Drilled holes 2 Louvered shutter      4 Key punched      7 Torch cut      10 Other (specify) . . . . .								
Screen-Perforation Dia. <b>16</b> in. to <b>485</b> ft. Dia in. to ft. Dia in. to ft.													
Screen-Perforated Intervals: <del>xxxx</del> Perf <b>225-300</b> ft. <del>xxxx</del> Screen <b>300-360</b> ft. <del>xxxx</del> Perf <b>360-460</b> ft. <del>xx</del> Screen <b>460-480</b> ft.													
<del>xxxx</del> Perf <b>480-485</b> ft. to ft. From ft. to ft.													
Gravel Pack Intervals: From <b>10</b> ft. to <b>485</b> ft. From ft. to ft. From ft. to ft.													
5 GROUT MATERIAL: 1 Neat cement      2 Cement grout      3 Bentonite      4 Other . . . . .													
Grouted Intervals: From <b>0</b> ft. to <b>10</b> ft. From ft. to ft. From ft. to ft.													
What is the nearest source of possible contamination:					10 Fuel storage      14 Abandoned water well 1 Septic tank      4 Cess pool      7 Sewage lagoon      11 Fertilizer storage      15 Oil well/Gas well 2 Sewer lines      5 Seepage pit      8 Feed yard      12 Insecticide storage      16 Other (specify below) 3 Lateral lines      6 Pit privy      9 Livestock pens      13 Watertight sewer lines <b>Center of 1/2 Section N/</b>								
Direction from well . . . . . How many feet . . . . . ? Water Well Disinfected? Yes . . . . . No <b>X</b>													
Was a chemical/bacteriological sample submitted to Department? Yes . . . . . No <b>X</b> . . . . . If yes, date sample was submitted . . . . . month . . . . . day . . . . . year: Pump Installed? Yes . . . . . No <b>X</b>													
If Yes: Pump Manufacturer's name . . . . . Model No. . . . . HP . . . . . Volts . . . . .													
Depth of Pump Intake . . . . . ft. Pumps Capacity rated at . . . . . gal./min													
Type of pump: 1 Submersible      2 Turbine      3 Jet      4 Centrifugal      5 Reciprocating      6 Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on <b>November</b> month <b>26</b> day <b>1980</b> year													
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>208</b>													
This Water Well Record was completed on <b>December</b> month <b>10</b> day <b>1980</b> year under the business name of <b>Minter Wilson Drilling Co., Inc.</b> by (signature) <i>M. Wilson</i>													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
						<b>Test log attached</b>							
ELEVATION:													
Depth(s) Groundwater Encountered 1. . . . . ft. 2. . . . . ft. 3. . . . . ft. 4. . . . . ft. (Use a second sheet if needed)													
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.													

October 29, 1980

Minter-Wilson Ulysses

Galen Meyers

Grant County

Location: SE 9-27-35 - Approx. 20' north of well  
Static Water Level - 185'

Ty #2

0	1	Top Soil
1	65	Brown Clay
65	110	Fine to Med. Sand & Gravel (Loose)
110	133	Med. to Coarse Gravel (Loose)
133	196	Fine to Med. Sand & Gravel 10% Clay (Loose)
196	223	Brown Clay
223	272	Fine to Med. Sand & Gravel 10% Clay (Loose)
272	275	Brown Clay
275	359	Fine to Med. Sand & Gravel 10% Clay (Loose)
359	365	Brown Clay 30% Gravel
365	402	Brown Clay (Tight)
402	426	Brown Clay & White Rock (Tight)
426	449	Brown & Gray Clay with White Rock (Hard)
449	455	Gray Yellow & Brown Clay with White Rock (Hard)
455	482	Fine to Med. Sand & Gravel with Brown Rock (Fairly Loose) (Hard Streaks)
482	505	Gray Yellow & Brown Clay with Brown Rock (Hard)
505	515	Blue Shale (Hard)
515	525	Blue Shale Mixed with Gray Yellow & Red (Hard)

T.D. 485'