



USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|   |   |   |   |                                  |   |
|---|---|---|---|----------------------------------|---|
| 1. Location of well:  | County<br><b>Grant</b>  | Fraction<br><b>NW 1/4 SE 1/4 NW 1/4</b> | Section number<br><b>21</b>   | Township number<br><b>T 27 S</b> | Range number<br><b>R 35 W</b>   |
| 2. Distance and direction from nearest town or city:<br><b>20 south of Garden City on US 83, 16 west, 1/2 north, Street address of well location if in city: 1/2 east</b> |   |   | 3. Owner of well: <b>Alexander Bros.</b><br>R.R. or street:<br>City, state, zip code: <b>Ulysses, Ks. 67880</b>   |                                  |   |
| 4. Locate with "X" in section below:<br>N<br>W<br>E<br>S<br>1 Mile<br>1 Mile  |   |   | Sketch map:<br>   |                                  |   |
| 5. Type and color of material   |   |   | From  | To                               | 6. Bore hole dia. <u>26</u> in. Completion date <u>11-20-76</u><br>Well depth <u>385</u> ft.  |
|   |   |   |   |                                  | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug<br><input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary  |
|   |   |   |   |                                  | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other  |
|   |   |   |   |                                  | 9. Casing: Material <u>Steel</u> Height: Above <u>surface</u><br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in.<br>RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft.<br>Dia. <u>16</u> in. to <u>386</u> ft. depth; Wall Thickness: inches or<br>Dia. <u>   </u> in. to <u>   </u> ft. depth; gage No. <u>.250</u> |
|   |   |   |   |                                  | 10. Screen: Manufacturer's name <u>Johnson</u><br>Type <u>galv.</u> Dia. <u>16"</u><br>Slot/gauze <u>   </u> Length <u>20</u> ft.<br>Set between <u>360</u> ft. and <u>380</u> ft.<br>Perf: <u>160-360</u> ft. and <u>380-385</u> ft.<br>Gravel pack? <u>yes</u> Size range of material <u>2" down</u>  |
|   |   |   |   |                                  | 11. Static water level: <u>195</u> ft. below land surface Date <u>9-14-76</u> mo./day/yr.   |
|   |   |   |   |                                  | 12. Pumping level below land surfaces:<br><u>210</u> ft. after <u>3</u> hrs. pumping <u>1200</u> g.p.m.<br><u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m.<br>Estimated maximum yield <u>1200</u> g.p.m.   |
|   |   |   |   |                                  | 13. Water sample submitted: <u>   </u> mo./day/yr.<br>Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>   </u>   |
|   |   |   |   |                                  | 14. Well head completion:<br><u>   </u> Pitless adapter <u>12</u> Inches above grade  |
|   |   |   |   |                                  | 15. Well grouted? <u>yes</u><br>With: <u>   </u> Neat cement <u>   </u> Bentonite <input checked="" type="checkbox"/> Concrete<br>Depth: From <u>0</u> ft. to <u>10</u> ft.   |
|   |   |   |   |                                  | 16. Nearest source of possible contamination: <u>N/A</u><br>ft. <u>   </u> Direction <u>   </u> Type <u>   </u><br>Well disinfected upon completion? <u>   </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>   |
|   |   |   |   |                                  | 17. Pump: <u>   </u> Not installed<br>Manufacturer's name <u>Goulds - US Pump</u><br>Model number <u>12 JHC</u> HP <u>200</u> Volts <u>   </u><br>Length of drop pipe <u>280</u> ft. capacity <u>1200</u> g.p.m.<br>Type:<br><u>   </u> Submersible <input checked="" type="checkbox"/> Turbine<br><u>   </u> Jet <u>   </u> Reciprocating<br><u>   </u> Centrifugal <u>   </u> Other                       |
| 18. Elevation:  | 19. Remarks:<br> |   | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.<br><b>Minter-Wilson Drilling Co. 208</b><br>Business name License No. <u>   </u><br>Address <u>Box A Garden City, Ks.</u><br>Signed <u>   </u> Date <u>5-13-77</u><br>Authorized representative |                                  |   |

27 35 W  
 Sec 21 NW SE NW  
 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
**Professionals**

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

ARLIN ALEXANDER  
GRANT COUNTY  
7-13-76

Location: NW  $\frac{1}{4}$  21-27-35 200 Ft. east of #1  
Static Water Level- 140'

Test #

|     |     |                              |
|-----|-----|------------------------------|
| 0   | 4   | Top soil                     |
| 4   | 52  | Brown clay                   |
| 52  | 64  | Fine to md. sand             |
| 64  | 84  | Brown clay                   |
| 84  | 312 | Fine to med. sand and gravel |
| 312 | 352 | Brown sandy clay             |
| 352 | 382 | Fine to med. sand and gravel |
| 382 | 427 | Fine to med. sand 15% clay   |
| 427 | 440 | Yellow clay and brown rock   |

*Drilled on this.*