

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name	Fraction NW 1/4 NE 1/4 SE 1/4	Section number 35	Town number T-27-B	Range number R-35-W
Distance and direction from nearest town or city: 6 miles East-6 1/2 north and 1/4 west of Hickok <small>Street address of well location if in city:</small>				3 Owner of well: Glen Koehn Address:		
Locate with "X" in section below: N W E NW 1/4 NE 1/4 SE 1/4 S 1 Mile		Sketch map: 1/4 mile West North Nickok 6 miles East 6 1/2 miles North		4 Well depth: 525 ft. Date of completion _____ Well diameter 26 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____		
From To				7 Casing: Material steel Height: above/below _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 525 ft. depth Weight 34.25 lbs./ft. _____ Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Manufacturer Johnson Type Galvanized Dia. 16 Slot/groze 100x100 Length 40 Set between 380 ft. and 400 ft. 415-435 *ittings: See Remarks Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 down		
9 Static water level: 220 ft. below land surface Date 5/10/76				10 Pumping level below land surfaces: 240 ft. after 4 hrs. pumping 1200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1800 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 2 inches above grade				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: none ft. _____ Direction In Field Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
15 Pump: Manufacturer's name Goulds Model number 14 M HP 150 Volts _____ Length of drop pipe 300 ft. capacity 1600 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. K.I. Drilling Co., Inc. 263 Business name License No. Address Box 669 Ulysses, Ks. Signed M. Joyce Brubaker Date 5/25/76 Authorized representative		
				16 Remarks: elevation Drilling Sub Contracted to Minter-Wilson Drilling. Lakewood-slot 125x66 set between 280 to 380, 400 to 415, 435 to 525.		

27 35W 35 NW NESE