

18,252 D2

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME STACY KOEHN
COUNTY GRANT
DATE 1-18-10

LOCATION: NE 1/4 12-27-35 - SOUTH ON DEERFIELD TO THE COUNTY LINE
- 2 MILES SOUTH, 1-3/4 MILES EAST,
1/4 MILE NORTHWEST & 1/4 MILE EAST
TO WELL - 600 FT. NORTH OF EXISTING WELL

STATIC WATER LEVEL 288 FT.

TEST #1

0' TO 2' - TOP SOIL
2' TO 4' - BROWN SANDY CLAY
4' TO 21' - FINE SAND
21' TO 54' - BROWN CLAY
54' TO 74' - FINE TO MEDIUM SAND & GRAVEL
74' TO 235' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE
235' TO 258' - BROWN CLAY
258' TO 288' - FINE TO MEDIUM SAND & GRAVEL
288' TO 315' - BROWN CLAY WITH SMALL GRAVEL STREAKS
315' TO 323' - FINE TO MEDIUM SAND & GRAVEL
323' TO 380' - FINE TO MEDIUM SAND & GRAVEL - CLAY STREAKS - TIGHT
380' TO 425' - BROWN CLAY
425' TO 479' - BROWN FLACKY CLAY
479' TO 487' - BROWN YELLOW CLAY
487' TO 528' - BROWN YELLOW GRAY CLAY
528' TO 560' - SHALE - HARD PULL DOWN