

Sent 6-21-77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 6	Township number T 27 S	Range number R 36 E
2. Distance and direction from nearest town or city: Street address of well location if in city:		9 miles North + 3 1/2 mi. East of Ulysses, Kansas		3. Owner of well: Don Phelps R.R. or street: Rt. #1 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 3/8 in. Completion date 3-24-77 Well depth 400 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Surface + fine Sand		0		20		9. Casing: Material Styro Height: Above or below Threated <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 400 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0-0320 320
Sand		20		100		10. Screen: Manufacturer's name Sanbaver Plastic Pipe Co. Type Styro Dia. 5 Slot/gauze 3/16 (1/16) Length 60 Set between 340 ft. and 400 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 8-1/4
Brown Clay		100		140		11. Static water level: 160 mo./day/yr. ft. below land surface Date 3-24-77 MNC
Blue Clay		140		260		12. Pumping level below land surfaces: N.A. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
Sand + Br. clay strips 40%		340		380		13. Water sample submitted: N.A. mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date 3-22
Coarse Sand		380		400		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 16 inches above grade
						15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Mortar <input type="checkbox"/> Concrete Depth: From 8 ft. to 20 ft.
						16. Nearest source of possible contamination: ft. 150 Direction W Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number N.A. HP 2 Volts 230 Length of drop pipe 300 ft. capacity 13 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wagner Drilling 253 Business name Box 10 License No. Address Ulysses, Ks. Date 4-1-77 Signed Wagner Drilling Authorized representative Form WWC-5
18. Elevation:		19. Remarks: Concrete slab to be installed by customer at surface of ground.				
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment