


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant County	Fraction 1/4 1/4 SW 1/4	Section number 10	Township number T 27 S R 36	Range number 36
2. Distance and direction from nearest town or city: 6 North of Ulysses to County Road, 6 East, 2 1/4 North, 1/4 East, Street address of well location if in city: 150' South of Pivot			3. Owner of well: Dale Corley R.R. or street: 114 W Pine City, state, zip code: Garden City, KS 67846		
4. Locate with "X" in section below: 			Sketch map: 6. Bore hole dia. 26 in. Completion date 12-28-78 Well depth 386 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 386 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
			10. Screen: Manufacturer's name Johnson Type Johnson Calv. D 100-16" Slot/gauze 0-216 Plain 216-276 Perf. Set between 276-296 Screen 296-341 Perf. 341-361 Screen 361-386 Perf. Gravel pack yes Size range of material 1/4 to 5/8		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 205 ft. below land surface <input checked="" type="checkbox"/> site		
			12. Pumping level below land surfaces: 219 ft. after 2 hrs. pumping 750 g.p.m. 238 ft. after 4 hrs. pumping 1300 g.p.m. Estimated maximum yield 1300 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 4 stg. 14" JHC Bowl Model number <input type="checkbox"/> HP 200 Volts <input type="checkbox"/> Length of drop pipe 360 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed Minter Wilson Date 12/27/78 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

P.O. Box A GARDEN CITY, KANSAS 67840
November 18, 1978

Dale Corley
Grant County

Location: S. W. $\frac{1}{4}$ 10-27-36 150' South of Pivot
Static Water Level - 200

Test # 3

0	1	Top Soil
1	16	Brown Clay
16	59	Sand & Clay
59	103	Brown Clay (tight)
103	127	Med. to coarse Gravel (loose)
127	167	Brown Clay
167	185	Fine to med. sand & fine gravel (loose)
185	215	Fine to med. sand and gravel (loose)
215	254	Fine to med. sand and fine gravel 10% Clay (loose)
254	300	Fine to med. sand and gravel (loose)
300	306	Brown Clay
306	320	Fine to med. sand and gravel 10% Clay (loose)
320	335	Brown Sandy Clay 35% Gravel
335	344	Brown Sandy Clay
344	365	Fine to med. sand and gravel (loose)
365	378	Brown Clay
378	384	Fine to med. sand and gravel (loose) (Small hard streaks)
384	395	Brown Clay with Brown & White Rock (t)
395	425	Brown & Gray Clay (tight)

T. D. 390