


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County GRANT	Fraction 1/4 1/4 NE 1/4	Section number 10	Township number T 27 S	Range number R 36 E/W
2. Distance and direction from nearest town or city: 1 mile south of County line 6 3/4 east south of Lakin Street address of well location if in city:			3. Owner of well: Dale Corley R.R. or street: 612 Center City, state, zip code: Garden City, Ks. 67846			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 5-11-76 Well depth 460 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lb./ft. Dia. 16 in. to 461 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 410 ft. and 450 ft. Perf. 200-410 ft. and 410-450, 450-460 Gravel pack? yes Size range of material 3/4" Down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 181.4 ft. below land surface Date 4-4-76		
				12. Pumping level below land surfaces: 186 ft. after 2 hrs. pumping 850 g.p.m. 199 ft. after 4 hrs. pumping 1325 g.p.m. Estimated maximum yield 1325 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 0 ft.		
				16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number HP 250 Volts Length of drop pipe 360 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Box A Garden City, Ks License No. Address Box A Garden City, Ks Signed [Signature] Date 8-3-76 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Dale Corley
Grant County
3-17-76

Location: NE $\frac{1}{4}$ 10-27-36 Between two Quarters

Test #8

0	1	Top soil
1	67	Brown clay
67	80	Fine sand, 15% clay
80	95	Brown clay & white rock (tight)
95	127	Fine to med. sand & Gravel, streak of coarse gravel (loose)
127	140	Med. to coarse gravel (loose)
140	250	Fine to med. sand & gravel (loose)
250	266	Blue clay
266	390	Fine to med. sand & gravel (loose)
390	460	Med. to coarse gravel (loose)
460	470	Gray & yellow clay with brown rock (hard)

T.D. 460

Static Water Level: 165