



*personal*

# MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Dale Corley  
GRANT COUNTY  
3-18-76

LOCATION: SE 11-27-36  
Between Two Quarters

STATIC WATER LEVEL: 165'

## TEST #10

0	1	Top Soil
1	23	Brown Clay
23	78	Brown Clay & Fine Sand
73	95	Brown Clay
95	110	Fine To Med. Sand (20%) Clay
110	123	Brown Clay
123	140	Med. To Coarse Gravel (10%) Clay (Loose)
140	211	Med. To Coarse Gravel (Loose)
211	230	Fine To Med. Sand & Gravel, Streaks Of Coarse Gravel (Loose)
230	367	Fine To Med. Sand & Gravel (Loose)
367	409	Brown Sandy Clay
409	420	Brown, Gray & Yellow Clay (Hard)