

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.


Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Grant</b>	Township name	Fraction <b>C NE 1/4</b>	Section number <b>17</b>	Town number <b>T27S</b>	Range number <b>R36W</b>
---------------------	------------------------	---------------	-----------------------------	-----------------------------	----------------------------	-----------------------------


Distance and direction from nearest town or city:  
**6 mi. North, 5 mi East, 1 3/4 Mi. North &  
Street address of well location if in city: 1 1/2 mi. West of Ulysses**

3 Owner of well: **Edna B. Petro**  
Address: **4712 W. 6th, Apt. 262  
Topeka, Kansas 66606**

Locate with "X" in section below:



Sketch map:



4 Well depth: **420** ft. Date of completion **1-25-75**  
Well diameter **26** in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug  
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry  
☒ Irrigation ☐ Air conditioning ☐ Commercial  
☐ Test well ☐

7 Casing: Material **Steel** Height: above **420** ft.  
Threaded ☐ Welded ☒ Surface **12** in.  
Diam. **16** in. Weight **34 1/2** lbs./ft.  
**0** in. to **420** ft. depth Drive shoe? ☐ Yes ☒ No  
**0** in. to **420** ft. depth

8 Screen:  
Manufacturer **Johnson**  
Type **Galvanized** Dia. **16** in.  
Slot/gauge **100x100** Length **20** ft.  
Set between **350** ft. and **370** ft. **50** lb. per Ft.  
Fittings: **See Remarks**  
Gravel pack ☒ Yes ☐ No Size range of material **1/2** down

9 Static water level:  
**154** ft. below land surface Date **1-30-75**

10 Pumping level below land surfaces:  
**205** ft. after **2** hrs. pumping **1300** g.p.m.  
ft. after hrs. pumping g.p.m.  
Estimated maximum yield g.p.m.

11 Water sample submitted:  
☐ Yes ☒ No Date

12 Well head completion:  
☐ Pitless adapter ☒ 12 in. Inches above grade

13 Well grouted? ☒ Yes ☐ No  
☒ Neat cement ☒ Bentonite ☐  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **in field**  
ft. Direction **none** Type  
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed  
Manufacturer's name **Peerless**  
Model number **used** HP **150** Volts  
Length of drop pipe **260** ft. capacity **1200** g.p.m.  
Type:  
☐ Submersible ☒ Turbine  
☐ Jet ☐ Reciprocating  
☐ Centrifugal ☐ Other

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this  
report is true to the best of my knowledge and belief.  
**K. I. Drilling Co. 263**  
Business name License No.  
Address **Box 669, Ulysses, Kan.**  
Signed **Bob Luper** date **1-27-75**  
Authorized representative

2	Type and color of material	From	To
	<del>Surface &amp; Fine Sand</del>	<del>0</del>	<del>15</del>
	<del>Fine Sand</del>	<del>15</del>	<del>75</del>
	<del>Brown Clay</del>	<del>75</del>	<del>90</del>
	<del>Sand</del>	<del>90</del>	<del>105</del>
	<del>Brown Clay</del>	<del>105</del>	<del>135</del>
	<del>Blue Clay</del>	<del>135</del>	<del>195</del>
	<del>Fine Sand &amp; Clay Strips</del>	<del>195</del>	<del>210</del>
	<del>Blue Clay</del>	<del>210</del>	<del>225</del>
	<del>Fine Sand</del>	<del>225</del>	<del>240</del>
	<del>Blue Clay</del>	<del>240</del>	<del>260</del>
	<del>Sand - Med. to Fine</del>	<del>260</del>	<del>300</del>
	<del>Brown Clay</del>	<del>300</del>	<del>315</del>
	<del>Coarse Sand</del>	<del>315</del>	<del>385</del>
	<del>Brown Sandy Clay 20%</del>	<del>385</del>	<del>420</del>
	<del>Brown Clay &amp; Lava Rock</del>	<del>420</del>	<del>465</del>
	<del>Brown Clay &amp; Blue Shale Strips</del>	<del>465</del>	<del>480</del>

16 Remarks: elevation  
Drilling Sub-contracted to:  
Minter-Wilson Drilling Co. License #208  
Garden City, Kn. 67846  
\* Lakewood Perf. - Slot - .125 X 66  
Set between 260' & 350'  
and 370' to 420'  
Topography:  
☒ Hill  
☐ Slope  
☐ Upland  
☐ Valley