

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Leroy Stuckey

Grant Co.

10-16-85

Location: SW 2-27-37

From Ulysses 10 miles No. 1½ miles East
¼ mile No. 150' NE of old well

Static water level 253'

Test # 1

- 0 4 Top soil
- 4 65 Brown sandy clay
- 65 140 Brown clay small streak of sand (Lost circulation)
- 140 240 Brown & Blue clay
- 240 265 Brown & Blue clay & fine to medium sand & gravel (50%)
- 265 291 Fine to medium sand & gravel (Loose)
- 291 305 Fine to medium sand & gravel with White & Brown rock (Loose)
- 305 312 Fine to medium sand & gravel, sticky clay (10%) Loose
- 312 320 Brown & White clay streak of fine to medium sand & gravel (40%)
- 320 334 Brown & Gray clay & fine sand mixture
- 334 368 Fine to medium sand, streak of clay (30%) loose
- 368 380 Brown, White & Yellow rock & fine sand streak of clay (10%) Loose
- 380 386 Brown, White & Yellow rock & clay mixture (50%)
- 386 438 Fine to medium sand & gravel, streak of clay (10%)
- 438 444 Brown, Yellow & White clay. Hard
- 444 450 Shalt. Hard pull down

RECEIVED

MAR 30 1987

BUREAU OF
ENVIRONMENTAL
REMEDIATION