


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Grant	Township name Sherman	Fraction NW NW SW	Section number 25	Town number 27S	Range number 37W
Distance and direction from nearest town or city: 7 miles north, 2 east, 1/2 south of Ulysses, Kansas				3 Owner of well: Elvin Methred Address: 217 Cottage Lane Canon City, Colo.			
Locate with "X" in section below: N 				Sketch map:			
2 Type and color of material				From	To	4 Well depth: 326.8 ft. Date of completion: 4-18-75 Well diameter: 27 in.	
Surface				0	2	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Brown clay				2	55	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
Medium sand				55	90	7 Casing: Material: steel Height: <u>above/below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface: 12 in. Diam. 16 inch Weight 36.8 lbs./ft. 1 0 in. to 194.11 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth	
Brown clay w/sand strips				90	200	8 Screen: Lakewood Manufacturer steel Dia. 16" Slot gauze 3/16 Length 2" slot Set between 194.11 ft. and 326.8 ft. Fittings: 1/4 x 5/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material —	
Medium to coarse sand w/clay strips 6-4-6-8 24ft				200	240	9 Static water level: 170 ft. below land surface Date 4-14-75	
Sandy clay				240	278	10 Pumping level below land surfaces: 300 ft. after 72.8 hrs. pumping 1000 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 1200 g.p.m.	
Dakota sandstone, loose lost circulation 49ft				278	327	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —	
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 2 inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
						14 Nearest source of possible contamination: ft. 600 Direction east Type creek Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation Drilled just up about 600 feet above the creek bed				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name Box 487, Ulysses, KS. License No. — Address M. Beard Signed M. Beard Date 4-22-75 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							