


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant	Fraction SE 1/4 NW 1/4 NE 1/4	Section number 26	Township number T 27 S R 38	Range number EW
2. Distance and direction from nearest town or city: from four way stop at Ulysses 7 miles north, 4 1/2 west			3. Owner of well: Mrs. Charles Shorter R.R. or street: RFD 3 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>25</u> in. Completion date _____ Well depth <u>428</u> ft. <u>10/13/78</u>		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material <u>steel</u> Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface _____ in. RMP <u>16</u> <u>225.9</u> Weight <u>36.8</u> lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. <u>.219</u>		
Surface			10. Screen: Manufacturer's name Lakewood Pipe of Texas		
Sandy clay			Type <u>steel</u> Dia. <u>16"</u>		
Fine to coarse sand, hitting sand, loose			Slot/gauze <u>3/16"</u> Length <u>202.3'</u>		
Brown sandy clay w/embedded sand strips			Set between <u>225.9</u> ft. and <u>428</u> ft. _____ ft. and _____ ft.		
Brown and gray clay			Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 x 5/8"</u>		
Gray sandy clay			11. Static water level: _____ mo./day/yr. <u>232</u> ft. below land surface Date <u>10/16/78</u>		
Brown & gray clay, sand strips (took water) lime shells			12. Pumping level below land surfaces: <u>350</u> ft. after <u>39.6</u> hrs. pumping <u>1100</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1200</u> g.p.m.		
Fine to medium sand embedded, w/brown sandy clay			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Fine to coarse sand, brown clay, lime shells, and sandy clay			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>24</u> Inches above grade		
Brown sandy clay, w/embedded sand strips			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>0</u> ft. to <u>10</u> ft.		
Brown broken shale, Dakota sandstone (lost Circ.)			16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>field</u> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No		
Brown broken shale, Dakota sandstone medium to tight			17. Pump: _____ <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
Brown sandstone (lost circulation) 80%			18. Elevation:		
Brown sandstone and shale 30%			19. Remarks:		
Red & brown sandstone 70%			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name Address Box 487, Ulysses, Ks. license No. Signed <u>M. Beard</u> Date <u>10/20/78</u> Authorized representative		
Brown sandstone, brown broken shale, lime shells			Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
Yellow chalk, brown broken shale, white clay & lime shells					
Blue shale, yellow chalk, lime shells tight & H (Use a second sheet if needed)					

27 38 26 SE NW NE
T R M Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5