

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Grant Fraction SE 1/4 SE 1/4 SE 1/4 Section number 30 Township number T 27 S R 38 E/W Range number	
2. Distance and direction from nearest town or city: 8 mi West 6" North Street address of well location if in city: Ulysses, K. 67880 3. Owner of well: Gary Baker R.R. or street: Rt. #3 City, state, zip code: Ulysses, Ks. 67880	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> <div> <p>Septic</p> <p>House</p> <p>Garage</p> <p>Well</p> </div> </div>	
5. Type and color of material	
Surface + fine sand	From 0 To 20
Brown clay	20 60
Sand	60 80
Brown clay	80 100
Sand	100 200
Blue + Brown clay	200 220
Coarse sand	220 260
Brown clay	260 330
Coarse sand	330 370
6. Bore hole dia. 9 7/8 in. Completion date April 77 Well depth 360 ft.	
7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material Styro Height: Above or below 12 in. Threading: Welded Surface 12 in. RMP: PVC Weight: 41 lbs./ft. Dia. 5 in. to 360 ft. depth Wall Thickness: inches or Dia. 0.320 in. to 0.320 ft. depth gage No. 0.320	
10. Screen: Manufacturer's name Scamflower Plastic Pipe Co. Type Styro Dia. 5 1/2 in. Slot/gauze 106 (1/6) Length 60 ft. Set between 240-260 ft. and 330-360 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/8	
11. Static water level: 130 ft. below land surface Date April 77 mo./day/yr.	
12. Pumping level below land surfaces: NA ft. after NA hrs. pumping NA g.p.m. Estimated maximum yield: NA g.p.m.	
13. Water sample submitted: NA mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date	
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12" inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8' ft. to 30' ft.	
16. Nearest source of possible contamination: Septic TANK ft. 200 Direction S.W. Type TANK Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: Not installed Manufacturer's name Goulds Model number NA HP 5 Volts 230 Length of drop pipe 320 ft. capacity 30 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wagner Drlg. 253 Business name License No. Address Ulysses, Ks. 67880 Signed Douglas Wagner Date April 1977 Authorized representative	

2738-30 SESESE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5