

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction 1/4 NW 1/4 NE 1/4	Section number 36	Township number T 27 S	Range number R 4W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 W., of Garden Plain, Kansas, 1 So. of old			3. Owner of well: Hahn & Hilger R.R. or street: City, state, zip code: R#1 Garden Plain, Kansas			
4. Locate with "X" in section below: Sketch map: 54 Hyway on SE Corner. Garden Plain, Kansas			6. Bore hole dia. 11 in. Completion date 3-31-78 Well depth 68 ft.			
5. Type and color of material			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
			8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other			
			9. Casing: Material styrene Height: Above or below Threading g1 Surface 12 in. RMP ☒ 5 68 PVC Weight 177 lbs./ft. Dia. 5 in. to 68 ft. depth Wall Thickness 1/8 inches or Dia. 5 in. to 68 ft. depth gage No. .200			
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/16 .06 Length 20' Set between 48 ft. and 68 ft. Set between 48 ft. and 68 ft. Gravel pack? yes Size range of material 1/4-1/8"			
			11. Static water level: 20 ft. below land surface Date 3-31-78 mo./day/yr.			
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____			
			14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade			
			15. Well grouted? yes 1-2 fine sand mix With: Neat cement 40" Bentonite 14 Concrete Depth: From 40 ft. to 14 ft.			
			16. Nearest source of possible contamination: NONE ft. ____ Direction ____ ☒ Type ____ Well disinfected upon completion? ☒ Yes ____ No			
			17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks: Flat Ground Septic system not installed at this time. No apparent source for contamination.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address M. Arnold Signed M. Arnold Date 4-29-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5