


1. Location of well: Stanton		County Stanton		Fraction NE 1/4 SE 1/4 NE 1/4		Section number 7		Township number T 27 S R 40		Range number 40	
2. Distance and direction from nearest town or city: Hiway Jct. 160 and 270 At Johnson, Ks. 10 miles north-2 east						3. Owner of well: Archie Nairn Johnson, Ks. 67855 R.R. or street: City, state, zip code:					
4. Locate with "X" in section below:  Sketch map: 1 Mile						6. Bore hole dia. 27 in. Completion date 4/28/77 Well depth 552.7 ft.					
5. Type and color of material						7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 231.6 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219					
10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16" Slot/gauze 3/16" Length 121.1' Set between 311.6 ft. and 432.7 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8"						11. Static water level: 66 ft. below land surface Date 2/2/77 mo./day/yr.					
12. Pumping level below land surfaces: 219 ft. after 12 hrs. pumping 1250 g.p.m. 225 ft. after 14 hrs. pumping 1380 g.p.m. Estimated maximum yield _____ g.p.m.						13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____					
14. Well head completion: <input type="checkbox"/> Pitless adapter 16 inches above grade						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: ft. _____ Direction _____ Type field Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: Topography: _____ <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						19. Remarks: W. A. Brown Perforation set between 231.6 ft. to 311.6 ft. and between 432.7 to 552.7 ft.					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drig. Co. 164 Business name _____ License No. _____ Address Ulysses, Kansas Box 48 Signed M. Beard Date 5/25/77 Authorized representative											