WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Stanton Stanton NE 1/4 NE 1/4 Se 2. Distance and direction from nearest town or city: 7½ miles north, 4 east, ½ west of Hiway Jct. 270 and 160 Street address of well location if in city: at Johnson, Ks.	3. Own	Section 22		Township number Range number	
Stanton NE 1/4 NE 1/4 Se 2. Distance and direction from nearest town or city: 7½ miles north, 4 east, ½ west of Hiway Jct. 270 and 160 Street address of well location if in city: at Johnson, Ks.	3. Own		2	$ T 27 S _R 40 $	1
	1				E/W
	- City, si			Tom Winger Johnson, Kansas	
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 27 in. Completion date Well depth 560 ft. 1-29-76	
NW NE E E E E E E E E E				7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse ro	otary
				8. Use: Domestic Public supply Industry X_ Irrigation Air conditioning Stock Lawn Oil field water Other	
S 1 Mile				9. Casing: Material St1 Height: Above or below Threaded Welded X Surface 12 RMP PVC Weight 36.8 lbs Dia 16 in to 1964. Septh Wall Thickness: inches	_in. ./ft.
5. Type and color of material		From	То	Diain. to ft. depth gage No219	_
Surface		0	2	10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16''	
Very fine sand		2	17	Slot/gauz2/16 Length 323.7 Set between 236.5 ft. and 560	
Medium to coarse sand w/clay breakers	<u> </u>	17	47	Gravel pack? X Size range of material 4 X 5	78
Brown clay		47	61	11. Static water level: mo./day 66 ft. below land surface Date $1-29-7$	<u>8</u> .
Very fine to fine sand w/clay breakers		61	137	12. Pumping level below land surfaces: 160 ft. after 6 hrs. pumping 1200 g.p	.m.
Fine to medium sand w/clay breakers		137	196	209 ft. after _6 hrs. pumping 1800 g.p	
Medium to coarse sand w/clay breakers 20)%	196	225	13. Water sample submitted: mo./day Yes X No Date	
Sandy clay, lime shells, w/bery fine sand st	trips	225	279	14. Well head completion:	
Yellow chalk, sandrock & Dakota		279	375	Pitless adapter 12 Inches above grade 15. Well grouted? X	-
Blue shale & Dakota		375	510	With: Neat cement Bentonite Conce Depth: FromO ft. toO ft.	rete
Cheyenne, Dakota and blue shale		510	560	16. Nearest source of possible contamination: NA ft Direction Type	
				Well disinfected upon completion? Yes 17. Pump: X Not installed	_ No
				Manufacturer's name Model number HP Volts_	
				Length of drop pipe ft. capacityg.p	.m.
				Type: Submersible Turbine	
(Use a second sheet if needed)				Jet Reciprocation Centrifugal Other	ng
18. Elevation: 19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this repo	ort .
Topography: Hill Slope				is true to the best of my knowledge and belief.	L64
Upland Valley				Signed M. Beard Date 1-3 Authorized representative	0-76