WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

					,
	County	Fraction	Section	n number	Township number Range number
1. Location of well:	Stanton	NW 1/4 NW 1/4 SE	1/4	23	T 27 S R 40
mwy jet. at Johnson, R.R. or street:					R. D. Floyd Johnson, Ks. 67855
Kiget adgre新主とはSlogetast jn cVy: north City, state, zi					
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. 26 in. Completion date
N N					Well depth 340. 2. 8-27-79
					7 Cable toolx Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary
					8. Use: Domestic Public supply Industry
₹ W					* Irrigation Air conditioning Stock
					Lawn Oil field water Other
					9. Casing: Material steel Height Above or below
<u>Y</u>					$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$
ı→ 1 Mile — → ı					Dia.16 in. to 229 # 2depth Wall Thickness: inches or
5. Type and color of material				То	Dia in. to ft. depth gage No19
Surface				1	10. Screen: Manufacturer's name Lakwood Pipe of Texas
Surface			0	2	TypesteelDig16''
Very fine to fine sand			2	17	Slot/gauze 3/16" Length 111'
			17	10	Set between <u>229.2</u> ft. and <u>340.2</u> ft.
Fine to medium sand			17	40	Gravel pack? X Size range of material 4 x 5/8!
Brown sandy clay w/fine sand strips			40	221	11. Static water level: mo./day/yr. 151 ft. below land surface Date 9-19-79
			ft. 22	235	12. Pumping level below land surfaces:
Fine to coarse sand w/clay breakers 12 ft.			22.	1 233	315 ft. after 72 hrs. pumping 500 g.p.m.
Cemented sand			23	239	ft. after hrs. pumping g.p.m. Estimated maximum yield 500 g.p.m.
Fine to coarse sand w/clay breakers				252	Estimated maximum yield
Cemented sand			25:	2 255	Yes _ X _No Date
			25.	5 281	14. Well head completion: Pitless adapter
Medium to coarse sand & sandrock				201	15. Well grouted?
Gray & brown shale, yellow chalk and sandrock			ck 28	1 294	With: X Neat cement Bentonite Concrete Depth: From 0 ft . to 10 ft .
Blue shale & Dakota			29	4 318	16. Nearest source of possible contamination: field
				-	ft Direction TypeType
Blue & brown shale & Dakota hard			31	8 330	Well disinfected upon completion? Yes X No
Blue & brown shale & Dakota			33	0 343	17. Pump: X Not installed Manufacturer's name
Blue 4 Didwii Shale 4 Dakota			1 33	0 0 10	Model number HP Volts
					Length of drop pipe ft. capacityg.p.m.
					Type: Submersible Turbine
				<u> </u>	Jet Reciprocating
(Use a second sheet if needed)					Centrifugal Other
18. Elevation: 19. Remarks:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
					is true to the best of my knowledge and belief.
Topography:					Houck Bros. Drlg. Co. 164
					Business name Box 487, Ulysses, KS.
Upland					Mari Ban 1 12-4-70
Valley					Signed Date