

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Stanton</u>		Fraction <u>SE 1/4 SE 1/4 SE 1/4</u>		Section number <u>26</u>		Township number <u>T 27 S</u>		Range number <u>R 40 E/W</u>	
2. Distance and direction from nearest town or city: <u>15 miles west, 6 north, 1 west of Ulysses, Ks.</u>						3. Owner of well: <u>Winger Cattle Co. Johnson, Ks. 67855</u>					
4. Locate with "X" in section below:						6. Bore hole dia. <u>9 1/2"</u> in. Completion date <u>12-20/77</u>					
<div style="display: flex; align-items: center;"> <div style="text-align: center;"> <p>Sketch map:</p> </div> <div style="margin-left: 20px;"> <p><u>HOUSE</u></p> <p><u>120 ft</u></p> <p><u>up</u></p> <p><u>up</u></p> <p><u>up</u></p> </div> </div>						Well depth <u>270</u> ft.					
5. Type and color of material						7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug					
						<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
Surface						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry					
Brown sandy clay						<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock					
Brown & gray clay w/fine sand strips						<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
Brown, sandy clay						9. Casing: Material <u>styrene</u> Height: Above or below					
Fine to medium sand w/clay breakers						Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in.					
Medium to coarse sand w/clay breakers and rock strips						RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.					
						Dia. <u>5</u> in. to <u>230</u> ft. depth Wall Thickness: inches or					
						Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>320</u>					
Brown clay w/clay strips and some very fine sand strips						10. Screen: Manufacturer's name <u>Sunflower</u>					
Brown clay w/fine to coarse sand strips						Type <u>styrene</u> Dia. <u>5"</u>					
Brown sandy clay w/very fine to fine sand strips						Slot/gauze <u>1/16"</u> Length <u>40</u>					
						Set between <u>230</u> ft. and <u>270</u> ft.					
						ft. and <u> </u> ft.					
						Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4"</u>					
Brown sandy clay, w/very fine sand strips						11. Static water level: <u>113</u> ft. below land surface Date <u>11/22/77</u>					
Fine to medium sand						12. Pumping level below land surfaces:					
Brown sandy clay w/fine to medium sand strips						<u>130</u> ft. after <u>12</u> hrs. pumping <u>12</u> g.p.m.					
						<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.					
						Estimated maximum yield <u>40</u> g.p.m.					
						13. Water sample submitted: <u> </u> mo./day/yr.					
						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>					
						14. Well head completion:					
						<input checked="" type="checkbox"/> Pitless adapter <u>24</u> inches above grade					
						15. Well grouted? <input checked="" type="checkbox"/>					
						With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete					
						Depth: From <u>0</u> ft. to <u>10</u> ft.					
						16. Nearest source of possible contamination:					
						ft. <u>180</u> Direction <u>north</u> Type <u>sewer</u>					
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
						17. Pump: <input checked="" type="checkbox"/> Not installed					
						Manufacturer's name <u> </u>					
						Model number <u> </u> HP <u> </u> Volts <u> </u>					
						Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.					
						Type:					
						<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine					
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating					
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:						20. Water well contractor's certification:					
19. Remarks:						This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					
Topography:						Houck Bros. Drilling Co. <u>164</u>					
<input type="checkbox"/> Hill						Business name <u> </u> License No. <u> </u>					
<input checked="" type="checkbox"/> Slope						Address <u>Box 487, Ulysses, Ks.</u>					
<input type="checkbox"/> Upland						Signed <u>M. Beard</u> Date <u>12/22</u>					
<input type="checkbox"/> Valley						Authorized representative					