


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stanton	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 35	Township number T 27 S R 41 E/W	Range number
2. Distance and direction from nearest town or city: 6 north, 1/2 west 1/4 south of intersection (hiway) at Johnson, Ks.			3. Owner of well: Galen Lane Johnson, Kansas 67855 R.R. or street: City, state, zip code:			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 27 in. Completion date 10-20-75 Well depth 324 ft.			
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Surface			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sandy clay, lime shells			2	30	9. Casing: Material St 1 Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft.	
Medium to coarse sand			30	57	Dia. 16 in. to 203.2 ft. depth; Wall Thickness: inches Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; Gauge No. 7/19.219	
Sandy clay			57	105	10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16" Slot/gauze 3/16 Length 80ft. 10 in. Set between 233.2 ft. and 273.7 ft. 283.7 ft. and 324 ft.	
Medium to coarse sand & yellow clay			105	165	Gravel pack? yes Size range of material 1/4 x 5/8	
Fine to medium sandw/clay & sand, lime shells			165	180	11. Static water level: <input type="checkbox"/> mo./day/yr. 132 ft. below land surface Date 10-9-75	
Fine to coarse sand w/clay breakers			180	202	12. Pumping level below land surfaces: 250 ft. after 11 hrs. pumping 1225 g.p.m. 285 ft. after 13 hrs. pumping 1600 g.p.m. Estimated maximum yield 1400 g.p.m.	
Medium to coarse sand 20 ft.			202	222	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
Medium to coarse sand w/clay breakers 12 ft.			222	242	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Very fine sand & clay breakers			242	260	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Medium to coarse sand 16 ft.			260	278	16. Nearest source of possible contamination: NA ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Nakota sandstone & sandrock 7 ft.			278	296	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Dakota sandstone 14 ft.			296	318	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487, Ulysses, Ks. Signed M. Beard Date 11-24-75 Authorized representative	
Gray clay and blue shale tight			318	325		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:			20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Johnson Irrigator Screen set from 203.2 to 233.2 ft. from 273.7 to 283.7 ft.				

2741035 SW NE 1/4 1/4 1/4 1/4