WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number Range number		
1. Location of well:	Stanton	NW 1/4 SW 1/4 SW	1/4		14	т 27 s	_R 42	E. ∕€ ∕
2. Distance and direction from nearest town or city: 8 miles north 7 west Street address of well location if in city: City, state					Syracuse, Ks. 67878			
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 27 in. Well depth 591 ft.	Completion date	77
NW	NE					7 Cable tool Rotary Hollow rod Jetted	Driven Dug Bored Rev	erse rotary
E						8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other Other Other Stock Lawn Oil field water Other Stock Inc Inc Surface 12_ in RMP PVC Weight 36 8 lbs./ft.		
5. Type and color of material					То	Dia in. to ft. depth gage No. <u>. 219</u> 10. Screen: Manufacturer's name <u>Lakewood</u>		
Surface					2	Pipe of Temas Type 3/16" steel 16" Slot/gauze 3/16" Length 387!		
Very fine snad & clay				2	28	Slot/gauze 3/16" Length 387! Set between 204 ft. and 591 ft.		
Sandy clay, lime shale & very fine sand					65	Gravel pack? X Size range of material 2 X 5/81		
Sndy clay, lime shale & very fine sand				65	129	11. Static water level: mo./day/yr. 142 ft. below land surface Date 2/16/77		
Brown clay & sandy clay					213	12. Pumping level below land		l g.p.m.
Medium to coarse sand w/embedded sand strips					237	_355 ft. after _16 hrs. pumping _900 g.p.m.		
Sandy clay w/embedded sand strips					251	13. Water sample submitted: mo./day/yr.		
Fine to medium sand w/clay strips					263	Yes x No Date 14. Well head completion:		
Brown sandy clayw/fine sand strips					322	Pitless adapter		
Brown clay, yellow chalk & Dakota					345	15. Well grouted? X With: X Neat cement Bentonite Concrete Depth: From 0 ft. to 10 ft.		
Blue shale, yellow chalk & Dakota					391	16. Nearest source of possible contamination:		
Blue & brown shale, Kakota & Cheyenne					468	ft Direction Type No Well disinfected upon completion? Yes No 17. Pump: Not installed Manufacturer's name		
Blue & brown shale & false red bed					485			
Rlue & brown shale & false red bed				485	501	Model number HP Volts Length of drop pipe ft. capacityg.p.m.		
Brown shale, false red bed, Cheyenne & Dakota				501	591	Type: Submersible	Turbii	ne
(Use a second sheet if needed)						Jet Centrifugal	Recip Other	rocating
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report		
						is true to the best of my know		is report
Topography: Hill						Houck Bros. Drilling Co. 164 Business name		
X Slope Upland						Address Box 487.	rd Date	(S
Valley						Authorized rep	resentative	_[]