

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County STANTON	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 36	Township number T 27 S	Range number R 42 10W
2. Distance and direction from nearest town or city: 4 north, 4 west, 1 north, 1 7/8 west, 1/8 north, 1/4 east & west of Johnson			3. Owner of well: Bill Teas R.R. or street: 1003 Manor Rd. City, state, zip code: Salina, KS		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			From	To	
			6. Bore hole dia. 26 in. Completion date 12-18-76 Well depth 380 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 381 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name Johnson Screen Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 30" Set between 340 ft. and 370 ft. Perf: 240-340 and 370-380 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" Down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 217 ft. below land surface Date 12-13-76		
			12. Pumping level below land surfaces: 235 ft. after 2 hrs. pumping 950 g.p.m. 241 ft. after 4 hrs. pumping 1275 g.p.m. Estimated maximum yield 1275 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter		
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: N/A Field ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goolds US Pumps Model number 14 JMC HP 200 Volts <input type="checkbox"/> Length of drop pipe 300 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Box A Garden City, KS License No. <input type="checkbox"/> Address Box A Garden City, KS Signed [Signature] Date 12-17-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

273420
 36
 SW NE SW
 1/4 1/4 1/4
 Sec

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BILL TEAS

STANTON COUNTY

11-11-76

Location: 27 36-27-42 north east corner of 4
Static Water Level- 205'

Test #2

0	4	Top soil
4	93	Brown clay
93	284	Fine to med. sand and gravel
284	296	Brown clay
296	380	Fine to med. sand and gravel
380	387	Brown and yellow clay
387	425	Shale

T.D. 380