

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
COUNTY: STANTON		NW 1/4 NW 1/4 NE 1/4	2	T 27 S	R 43 W
Distance and direction from nearest town or city street address of well if located within city? FROM JOHNSON - 10 N ON HIGHWAY 27 - 12 W ON ROAD 2 - 1N 1/2W					
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # :		Application Number:			
City, State, ZIP code :		SYRACUSE, KS 67878-			
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 325 ELEVATION: 0			
		Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.			
		WELL'S STATIC WATER LEVEL 245 ft. below land surface measured on mo/day/yr 02/14/97			
		Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm			
		Estimated Yield 30 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm			
		Bore Hole Diameter 10 in. to 325 ft., and in. to 0 ft.			
		WELL WATER TO BE USED AS: DOMESTIC			
		Was a chemical/bacteriological sample submitted to department? No ;			
		If yes, mo/day/yr sample was submitted Water well disinfected? Yes			
5 TYPE OF BLANK CASING USED: PVC		CASING JOINTS: GLUED			
Blank casing diameter 5 in. to 325 ft., Dia in. to 0 ft., Dia in. to 0 ft.					
Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21					
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC					
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT					
SCREEN PERFORATED INTERVALS:		From 280 ft. to 320 ft., From 0 ft. to 0 ft.			
GRAVEL PACK INTERVALS:		From 0 ft. to 0 ft., From 0 ft. to 0 ft.			
		From 25 ft. to 325 ft., From 0 ft. to 0 ft.			
		From 0 ft. to 0 ft., From 0 ft. to 0 ft.			
6 GROUT MATERIAL BENTONITE					
Grout Intervals: From 0 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.					
What is the nearest source of possible contamination: SEPTIC TANK					
Direction from well? WEST		How many feet? 200			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	TOPSOIL CLAY			
20	40	CLAY FINE SAND			
40	60	CLAY			
60	80	CLAY FINE SAND			
80	100	CLAY THIN ROCK LAYER			
100	120	CLAY THIN ROCK LAYER FINE SAND			
120	160	FINE - MED SAND			
160	180	FINE SAND THIN ROCK LAYER			
180	220	FINE - MED SAND			
220	260	FINE SAND COARSE SAND			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 02/15/97 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's license No. 179 This Water Well Record was completed on (mo/day/yr) 02/27/97 by (signature) <i>David Cook</i>					

(Continued)

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
COUNTY: STANTON		NW 1/4 NW 1/4 NE 1/4	2	T 27 S	R 43 W
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # :		Application Number:			
City, State, ZIP code :		SYRACUSE, KS 67878-			
FROM	TO	LITHOLOGIC LOG			
260	280	MED-COARSE SAND CLAY			
280	300	CLAY MED-COARSE SAND			
300	320	MED-COARSE SAND			
320	340	CLAY ROCK LAYERS			