

USE TYPEWRITER OR BALL-POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Stanton	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 2	Township number T 27 S R 43	Range number W
----------------------	--------------------------	---	----------------------------	---------------------------------------	--------------------------

2. Distance and direction from nearest town or city: 17 S. & 12 W. of Syracuse Street address of well location if in city:	3. Owner of well: Ralph Cook R.R. or street: City, state, zip code: Syracuse, KS 67878
---	--

4. Locate with "X" in section below:

Sketch map:
Well drilled 5-6-76

6. Bore hole dia. 26 in. Completion date 5-12-76
Well depth 416 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material Steel Height: Above ground _____
Threaded _____ Welded Surface 12 in.
RMP _____ PVC _____ Weight 36 lbs./ft.
Dia. 16 in. to 416 ft. depth Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth gage No. .250

5. Type and color of material

	From	To
See attachment		

10. Screen: Manufacturer's name Johnson

Type Continuous Dia. 16"
Slot/gauge 60 & 100 Length 130'
Set between 268 ft. and 298 ft.
310 ft. and 330 ft.
Gravel pack? Yes Size range of material 1/4 x 1/8

11. Static water level: _____ mo./day/yr.
226 ft. below land surface Date 5-12-76

12. Pumping level below land surfaces:
287 ft. after _____ hrs. pumping 372 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.

13. Water sample submitted: _____ mo./day/yr.
Yes No _____ Date _____

14. Well head completion:
 Pitless adapter 12 inches above grade

15. Well grouted? Yes
With: Neat cement Bentonite _____ Concrete _____
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: None observed
ft. _____ Direction _____ Type _____
Well disinfected upon completion? _____ Yes No _____

17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible _____ Turbine _____
 Jet _____ Reciprocating _____
 Centrifugal _____ Other _____

(Use a second sheet if needed)

18. Elevation:
Flat
Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Henkle Drilling & Supply 145
Business name License No. _____
Address **Box 639 Garden City, KS**
Signed *J. Henkle* Date **5-28-76**
Authorized representative

DRILLERS TEST LOG

CUSTOMERS NAME Ralph Cook DATE 5-4-76
 STREET ADDRESS _____ TEST # 1
 CITY & STATE Syracuse, KS DRILLER Livingston
 COUNTY Stanton QUARTER NW SECTION 2 TOWNSHIP 27 RANGE 49
 LOCATION 30 ft. west of pivot

%	DRILLED FOOTAGE		Description of Strata	Static Water Level
	From	Pay To		Proposed Well Depth
	0		2	
			40	
	40		50	
	50		95	
	95		100	
	100		206	
	206		210	
	210		240	
50	240	35	275	
65	275	23	298	
	298		310	
70	310	20	330	
	330		337	
80	337	10	347	
	347		355	
Very Good	355	45	410	
	410		414	
	414		420	
TOTAL DEPTH OF WELL 416 FT.				
Set up southeast				
Dig pit on the south				

ARDEN CITY, KANSAS
 HONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
 PHONE 675-4311

EST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****