

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Kingman	Fraction SE 1/4 NE 1/4	Section number 26	Township number T 27 S R	Range number 5W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1/2 North of 54, 1 West of Cheney Reservoir Road			3. Owner of well: R.R. or street: Ed Needham R. R. #2 Cheney, Kansas		
4. Locate with "X" in section below: Sketch map: 1/4 North on the West side of the Road. Cheney, Kansas			6. Bore hole dia. 11 in. Completion date _____ Well depth 60 ft. 7-5-77		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material styrene Height: Above or below _____ Threaded _____ Welded 81 Surface _____ 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gage No. .200		
			10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot/groove .06 Length 22' Set between 38 ft. and 60 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/4-1/8"		
Topsoil			11. Static water level: _____ 15 ft. below land surface Date 7-5-77		
Fine Sand & Clay Balls			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Fine Sand			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
Red shale			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 capped inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes 1-2 find sand mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete _____ Depth: From 40" ft. to 14 ft.		
			16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Septic System not installed at this time. No apparent source for contamination.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business address Wichita, Kansas 67209 Address _____ Signed M. Arnold Date 8-28-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5