

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

*300 ft*

1. Location of well: County Franklin Fraction C 1/4 SW 1/4 NE 1/4 Section number 31 Township number T 27<sup>S</sup> Range number R 5<sup>W</sup> E/W

2. Distance and direction from nearest town or city: 1 mile east Midway. Street address of well location if in city: 1/2 South

3. Owner of well: DR Faust Oil Co. R.R. or street: City, state, zip code: Wichita Kansas

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 4 in. Completion date 5-16-78  
Well depth 40 ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material  Height: Above or below  
Threaded  Welded  Surface 12 in.  
RMP  PVC  Weight 278 lbs./ft.  
Dia. 5 in. to 40 ft. depth Wall Thickness: inches or  
Dia. 5 in. to 40 ft. depth gage No. 200

5. Type and color of material	From	To
<u>Clay</u>	<u>0</u>	<u>12</u>
<u>Sand + Clay</u>	<u>12</u>	<u>30</u>
<u>Gravel</u>	<u>30</u>	<u>37</u>
<u>Red Sand</u>	<u>37</u>	<u>40</u>

10. Screen: Manufacturer's name Shotcrete  
Type Saw Dia. 5  
Slot/gauge 8 Length 20  
Set between 8 ft. and 20 ft.  
ft. and 20 ft.  
Gravel pack?  Size range of material 1/8-1/4

11. Static water level: 15 ft. below land surface Date 5-16-78 mo./day/yr.

12. Pumping level below land surfaces:  
18 ft. after 1 hrs. pumping 60 g.p.m.  
ft. after     hrs. pumping     g.p.m.  
Estimated maximum yield 60 g.p.m.

13. Water sample submitted:     mo./day/yr.  
 Yes  No Date    

14. Well head completion:  
 Pitless adapter 12 inches above grade

15. Well grouted?   
With:  Neat cement  Bentonite  Concrete  
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:  
ft.     Direction     Type      
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name      
Model number     HP     Volts      
Length of drop pipe     ft. capacity     g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

(Use a second sheet if needed)

18. Elevation: Topography:  Hill  Slope  Upland  Valley

19. Remarks:

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
    Business name License No.      
Address      
Signed     Date 5-31  
Authorized representative

27-50-31  
R  
S  
W  
E  
Sec  
1/4  
1/4  
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5