

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kingman	Fraction NE_{1/4} NE_{1/4} NE_{1/4}	Section number 36	Township number T 27 S R 7 (EW)	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 4 E. Kingman, Ks.			3. Owner of well: Steve Stucky R.R. or street: RR#2 City, state, zip code: Kingman, Ks. 67068			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 3/4 in. Completion date 5/26/77 Well depth 34 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	4	9. Casing: Material Plastic Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1 1/2 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 24 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
Clay		4	10	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5" Slot/gauze 1/8 Length 10' Set between 24 ft. and 34 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/8		
V F Sand		10	15	11. Static water level: <input type="checkbox"/> mg./day/yr. 22 ft. below land surface Date 5/26/77		
Clay		15	22	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield N/A g.p.m.		
Course Sand		22	34	13. Water sample submitted: ____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Red Bed		34	-	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
				16. Nearest source of possible contamination: ft. 60 Direction NW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wells Drilling Co. 112 Business name License No. ____ Address 1030 E. Hwy 54 Signed Dean & Wallace Date 5/28/77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27 - 70E
 36
 NE NE NE
 1/4 1/4 1/4
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5