USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SENENE

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Kingman	Hossier	~~SE1/4 SE1/4 SW1/4~~	35	T27S	R8W

Distance and direction from nearest town or city: 2 1/2 of Kingman

Street address of well location if in city:

3 Owner of well: Stephen Arnold.

Address: Kingman Kns. RR#1

Locate with "X" in section below: Sketch map:

N, W, E, S, 1 Mile

4 Well depth: 35 ft. Date of completion Aug 25-75
Well diameter 9 1/4 in. Well Bore

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐

7 Casing: Material Plast Height: above below
Threaded ☐ Welded ☐ Surface 16 in.
Diam. 5 in. to 35 ft. depth Weight 20 lbs./ft.
Drive shoe? ☐ Yes ☒ No
in. to ft. depth

2 Type and color of material	From	To
top - Clay	0'	14'
Sand + Fine Gravel	14'	35'
Red Bed.		

(use a second sheet if needed)

8 Screen:
Manufacturer Jess - Fowell
Type RMP Dia. 5"
Slot/gauze 1/8 Length 10'
Set between 25 ft. and 35 ft.
Fittings:
Gravel pack ☑ Yes ☐ No Size range of material 1/8" x 3/8"

9 Static water level:
14 ft. below land surface Date Aug 25-75

10 Pumping level below land surfaces:
ft. after hrs. pumping NA g.p.m.
ft. after hrs. pumping g.p.m.
Estimated maximum yield g.p.m.

11 Water sample submitted:
☐ Yes ☑ No Date

12 Well head completion:
☑ Pitless adapter 11" inches above grade

13 Well grouted? ☑ Yes ☐ No
☑ Neat cement ☐ Bentonite ☐
Depth: From 3 ft. to 12 ft.

14 Nearest source of possible contamination:
ft. 300 Direction SE Type Septic tank
Well disinfected upon completion? ☑ Yes ☐ No

15 Pump: ☑ Not installed
Manufacturer's name NA
Model number HP Volts
Length of drop pipe ft. capacity g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation

Topography:
☑ Hill
☐ Slope
☐ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Wells Drilling Co 112
Business name License No.
Address 1030 Hiway 54 East
Signed Dale Wells Date Aug 26-75
Authorized representative
Kingman Kns

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5