

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County <b>Kingman</b>	Fraction <b>1/4 cse 1/4 SW 1/4</b>	Section number <b>4</b>	Township number <b>T 27 S</b>	Range number <b>R 9W E/W</b>
2. Distance and direction from nearest town or city: <b>1/2 e</b>			3. Owner of well: <b>Abercrombie Drilling, Ing</b>		
Street address of well location if in city: <b>Penalosa, Ka.</b>			R.R. or street: <b>R 1</b>		
			City, state, zip code: <b>Great Bend, Ks 67530</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>8</b> in. Completion date _____	
				Well depth <b>105</b> ft. <b>8-4-77</b>	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<b>Top Soil Clay</b>		<b>0</b>	<b>35</b>	9. Casing: Material _____ Height: Above or below <b>XXXX</b> Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <b>5</b> in. to <b>105</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>Sch 40</b>	
<b>Sandy Clay</b>		<b>35</b>	<b>75</b>	10. Screen: <b>Jetstream</b> Type <b>Pvc</b> Dia. <b>5</b> Slot/gauze <b>1/16"</b> Length <b>20'</b> Set between <b>85</b> ft. and <b>105</b> ft. _____ ft. and _____ ft.	
<b>Sand-Gravel</b>		<b>75</b>	<b>105</b>	Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/8-3/4"</b>	
				11. Static water level: _____ mo./day/yr. <b>40</b> ft. below land surface Date <b>8-4-77</b>	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>50</b> g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
				16. Nearest source of possible contamination: <b>oil</b> ft. <b>60</b> Direction <b>n</b> Type <b>Test</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Kelly's Waterwell Ser 186</b> Business name _____ License No. _____ Address <b>R2 Great Bend, Ks.</b> Signed <b>Kelly Price</b> Date <b>7-10-78</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 27 S  
 R 9W  
 Sec 4  
 CSE SW  
 1/4 1/4 1/4