## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

·	County	Fraction	·	Section	number	Township number Range number
1. Location of well:			W , ,,	,		
2 Distance and dis	Kingman	1/4 c 1/4 x		er of well	. <b>1</b>	T 27 S   R 9 E
						110 N. Market
1-W 3/4-N east side from Penalosa, Ks.  Street address of well location if in city:  R.R. or street:  City, state, zip of						Wichita, Ks. 67202
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 8 in . Completion date
N						Well depth 120 ft. 4-6-76
======================================						7 Cable tool _XRotary Driven Dug
						Hollow rod Jetted Bored Reverse rotary
						8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock
						Lawn X Oil field water Other
						9. Casing: Material <b>DVC</b> Height: Above or <b>XXX</b>
					Threaded Welded Surface in.	
S 1→1 Mile						RMPPVCXWeightlbs./ft. Dia. 4in. to 120 ft. depth Wall Thickness: inches or
5. Type and color of material				From	То	Dia in. to ft. depth gage No237
						10. Screen: Manufacturer's name
sandy top	soil		,		10	
				1	2	Slot/g <b>XXX</b> 1/16 Length
clay				2	<u> </u>	Set betweenft. andft.
fine sand				3	8	Gravel pack? X Size range of material \frac{1}{23}/43/8
, ,					30	11. Static water level: mo./day/yr.
good clean sand & gravel				- 9		49 ft. below land surface Date4-6-76
clay				30	48	12, Pumping level below land surfaces:  60 ft. after 1 hrs. pumping 80 g.p.m.
sand				48	53	ft. after hrs. pumping g.p.m.
						Estimated maximum yieldg.p.m.
clay				53	65	
sand & clay				65	95	Yes X No Date  14. Well head completion:
				05	100	Pitless adapter Inches above grade
clay		- Alexandra - Alex		<del> </del>		15. Well grouted? X
good clean sand & gravel				100	120	With: X Neat cement Bentonite Concrete Depth: From ft. to ft.
						16. Negrest source of possible contamination: ft. Directionnw Type _gaswell
						Well disinfected upon completion? X Yes No
						17. Pump: X_ Not installed Manufacturer's name
-				<del>  </del>		Model number HP Volts
						Length of drop pipe ft. capacityg.p.m.
						Type: Submersible Turbine
						JetReciprocating
(Use a second sheet if needed)						Centrifugal Other
18. Elevation: 19. Remarks:						20. Water well contractor's certification:
						This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Topography:						Rosencrantz-Bemis 134
Hill Stars						Business name License No.
Slope X_ Upland						Address Great Bend, Kansas 6/630
Valley					,	Authorized epresentative