
USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215



Kansas State Dept. Of Health (Water Well Contractors) Forbes-Bldg. 740 Topeka, Kansas 66620

	County	Township name	Fraction		Section	on number		Town number	Range number
1 Location of well:	Kingman		SW ¼		15		27 S		9 W
Distance and directi	ion from nearest town or cit	y: 4 mi Nor	th d	3 Owner	r of well			& Sam Livi	ngston
Street address of we	II location if in city:	West of C	alista	Addr	ess:	K	ingm	an, Kansas	
Locate with "X" in s	section below:	Sketch map:	- Nacional de la Companya de la Comp	<u> </u>			4 We We	II depth: <u>195</u> ft. Do II diameter <u>30</u> in.	ate of completion $5/24$
	1 1 1 1 1 1 111							Cable tool Rotary Hollow rod Jetted	
w							6 Use	: Domestic Public Irrigation Air cor Test well	supply Industry
7	S S						Thr	ing: Material Stl He	orface <u>12</u> in.
	Mile-			······································			<u> 1</u>	6 in. to 27 ft. depth Di	rive shoe? Yes No
2	Тур	e and color of material			From	То	8 Scr	_ in. toft. depth	
Top soil				*	0	3	Ma Typ	nufacturer <u>Doerr</u> se <u>St1</u> Di t/gauze <u>1/8"</u> Le	ia. 16"
Med. to	coarse sand	d & gravel v	w/clay		3	31	Slo Set	t/gauze $\frac{1/8}{2.7}$ Le between $\frac{1}{2.7}$ ft. and $\frac{1}{2}$	ngth 68 ft
Clay		- 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1 - 18- 1			31	45	Fit Gre	tings: avel pack 🔀 Yes 🗌 No S	ize range of material
Med. to	coarse sand	d & gravel			45	107	9 5+4	tic water level: 2 ft. below land surface	
Clay					107	122		nping level below land surfa	aces: No Tart
Fine to	coarse sand	d & gravel			122	194		ft. after hrs. mated maximum yield	pumping g.p.m.
Red shal	Le				194	197	11 Wa	ter sample submitted:	
							12 We	Yes 💹 No Date Il head completion:	/Z Inches above grade
							13 We	Il grouted? Tyes	X No.
							Dep	Neat cement Bentonite	C/AY
			· · · · · ·				14 Ne		tamination: Farmla
							We	Il disinfected upon complet	ion? Yes Yo
							15 Pun Ma	nufacturer's name Lay	Not installed
							Mo Ler	del number $\frac{77087}{100}$ ft	P <u>(60</u> Volts 4(6) . capacity 700 g.m.p.
							Typ.		Turbine
	(use	a second sheet if needed)						Jet Certrifugal	Reciprocating Other
16 Remarks: elevat	ion						1	ter well contractor's certific s well was drilled under my	1
T !						_	rep	ort is true to the best of my	knowledge and belief.
Topography:]		e Western Co	License No.
Slope								dress Wichitz	Kansas 5/37
Upland Valley							Sig	ned	Date