

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County KINGMAN Fraction SW 1/4 NE 1/4 NE 1/4 Section number 18 Township number T 27 S R 9 W E 10 Range number	
2. Distance and direction from nearest town or city: 1/2 & 1/4 W OF PENALOSA Street address of well location if in city: PENALOSA	
3. Owner of well: CARLOS SCHWARTZ R.R. or street: City, state, zip code: CUNNINGHAM, KS	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> </div> <div> <p>WATER WELL X</p> <p>↓ ↓ ↓ DRAINAGE</p> </div> </div>	
6. Bore hole dia. 30 in. Completion date 3 MAY 77 Well depth 154 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material STL Height: (Above or below) 0 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 16 in. to 94 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
10. Screens: Manufacturer's name WA BROWN Type FRELO Dia. 16" Slot/gauze 1/8 Length 60' Set between 94 ft. and 154 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 1/2	
11. Static water level: <input type="checkbox"/> mo./day/yr. 66 ft. below land surface Date <input type="checkbox"/>	
12. Pumping level below land surfaces: 84 ft. after 2 hrs. pumping 800 g.p.m. 95 ft. after 1/2 hrs. pumping 1200 g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name NATIONAL Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 120 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
19. Remarks: CONCRETE SLAB POURED AT SURFACE	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CENTRAL WELL & PUMP 325 Business name License No. Address 1215 TAYLOR DR Signed JPHonomichl Date 3 MAY 77 Authorized representative	

T 27 - 9 W E 10 S R 9 W E 10