


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Kingman</u>	Township name <u>Eureka</u>	Fraction <u>NE NW SW</u>	Section number <u>33</u>	Town number <u>T 27 S</u>	Range number <u>R 9 W</u>
Distance and direction from nearest town or city: <u>4 1/2 S of Penaloosa, Kans.</u>			3 Owner of well: <u>Kansas Forestry, Fish & Game Box 1028 3/0 Game Div. Fruitt, Kansas 67124</u>			
Locate with "X" in section below: 			Sketch map:			4 Well depth: <u>72</u> ft. Date of completion <u>8-30-75</u> Well diameter <u>5</u> in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			This well was a 2" Tubular well. IT was pulled, a 10" hole drilled, 5" casing set etc. All Formations were mixed. Impossible to do more than guess at formation. Otherwise well has been completed according to State specifications and Forestry, Fish & Game purchase order no. 438235			
					7 Casing: Material <u>RMA</u> Height: <u>above</u> /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. Diam. <u>5</u> in. Weight <u>200</u> lbs./ft. <u>5</u> in. to <u>72</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					8 Screen: Manufacturer <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>10'</u> Set between <u>62</u> ft. and <u>72</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/16-3/8</u>	
					9 Static water level: <u>23</u> ft. below land surface Date <u>8-30-75</u>	
					10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>25</u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade <u>18"</u>	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: ft. <u>75</u> Direction <u>E</u> Type <u>Dry Pond</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Hank Brusewell Serv. 103</u> Business name _____ License No. _____ Address <u>1117 Stout</u> Signed <u>Joey Bruse</u> Date <u>8-31-75</u> Authorized representative	
16 Remarks: elevation <u>1670'</u>						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5