


1 LOCATION OF WATER WELL: County: SEDGWICK Fraction: NE 1/4 SW 1/4 SW 1/4 Section Number: 8 Township Number: T 28 Range Number: S 1	
Distance and direction from nearest town or city street address of well if located within city? 1/2 m EAST OF SCHULTE	
2 WATER WELL OWNER: MID CONTINENT INDUSTRIAL DEVELOPMENT RR#, St. Address, Box #: Box 12086 Board of Agriculture, Division of Water Resources City, State, ZIP Code: WICHITA, KS 67201 Application Number:	
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	4 DEPTH OF COMPLETED WELL: 98 ft. ELEVATION: Depth(s) Groundwater Encountered 1. 36 ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 36 ft. below land surface measured on mo/day/yr 10/20/81 Pump test data: Well water was 54 ft. after 4 hours pumping 140 gpm Est. Yield 160 gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter: 26 in. to 98 ft., and in. to ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below) Was a chemical/bacteriological sample submitted to Department? Yes No If yes, mo/day/yr sample was submitted BY REISS & GOODNESS ENG Water Well Disinfected? Yes No
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing diameter 8 in. to 8.6 ft. Dia. in. to ft. Dia. in. to ft. Casing height above land surface 12 in., weight 24.7 lbs./ft. Wall thickness or gauge No. 277 TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 7 Torch cut 9 Drilled holes 10 Other (specify) SCREEN-PERFORATED INTERVALS: From 86 ft. to 98 ft., From ft. to ft. GRAVEL PACK INTERVALS: From 50 ft. to 98 ft., From ft. to ft.	
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout intervals: From 0 ft. to 50 ft., From ft. to ft., From ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage Direction from well? EAST How many feet? 1600	
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) OCT 29, 1981 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 102 This Water Well Record was completed on (mo/day/yr) 11/5/81 under the business name of LAYNE WESTERN CO INC by (signature) <i>[Signature]</i> INSTRUCTIONS: Use typewriter or ball point pen, PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or cross the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Environmental Geology Section, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.	