

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>Sedgewick</u>		Fraction: <u>1/4 NW 1/4 NW 1/4</u>		Section number: <u>13</u>		Township number: <u>T 28 S</u>		Range number: <u>R 1 E</u>	
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>3711 West McArthur</u> <u>Wichita, Kas.</u>					3. Owner of well: <u>John Brammer</u> R.R. or street: <u>3711 West McArthur</u> City, state, zip code: <u>Wichita, Kansas</u>				
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile Sketch map:					6. Bore hole dia. <u>11</u> in. Completion date: <u>7-19-76</u> Well depth <u>55</u> ft.				
					7. Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary				
					8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other				
5. Type and color of material					9. Casing: Material <u>stycast</u> Height: <u>above</u> or below Threaded ☒ Welded ☐ Surface <u>12</u> in. RMP ☐ PVC ☐ Weight <u>12</u> lbs./ft. Dia. <u>5</u> in. to <u>55</u> ft. depth Well thickness: inches or Dia. <u>5</u> in. to <u>55</u> ft. depth gage No. <u>200</u>				
					10. Screen: Manufacturer's name <u>Sunflower plastic</u> Type <u>stycast</u> Dia. <u>5"</u> Clay gauze <u>100</u> Length <u>10 ft</u> Set between <u>45</u> ft. and <u>55</u> ft. Gravel pack <u>yes</u> Size range of material <u>1/4-1/8"</u>				
					11. Static water level: _____ mo./day/yr. <u>20</u> ft. below land surface Date <u>7-19-76</u>				
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.				
					13. Water sample submitted: _____ mo./day/yr. ☐ Yes ☐ No Date _____				
					14. Well head completion: <u>Capped</u> ☐ Pitless adapter <u>12</u> inches above grade				
					15. Well grouted? <u>yes</u> With: ☐ Neat cement ☐ Bentonite ☒ Concrete Depth: From <u>40</u> ft. to <u>14</u> ft.				
					16. Nearest source of possible contamination: <u>Septic Tank</u> ft. <u>60</u> Direction <u>NW</u> Type <u>Tank</u> Well disinfected upon completion? ☒ Yes ☐ No				
					17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other				
18. Elevation:					19. Remarks:				
Topography: ☒ Hill ☐ Slope ☐ Upland ☐ Valley					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harsh Well Pump</u> <u>236</u> Business name License No. Address <u>Wichita, Kansas</u> Signed <u>M. Arnold</u> Date <u>8-13-76</u> Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5