

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: SEDGWICK		NW ¼ SE ¼ SE ¼		15		T 28 S		R 1 /E/W	
Distance and direction from nearest town or city?				Street address of well if located within city? 6220 West 47th St. South Wichita, Kansas					
2 WATER WELL OWNER:		Bill Vanderhoff							
RR#, St. Address, Box # :		6220 West 47th St. So.							
City, State, ZIP Code :		Wichita, Kansas							
		Board of Agriculture, Division of Water Resources Application Number:							
3 DEPTH OF COMPLETED WELL		103 ft. Bore Hole Diameter 30 in. to ft. and in. to ft.							
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well							
1 Domestic 3 Feedlot		6 Oil field water supply 9 Dewatering 12 Other (Specify below)							
2 Irrigation 4 Industrial		7 Lawn and garden only 10 Observation well							
Well's static water level		13 ft. below land surface measured on 8 month 10 day 1979 year							
Pump Test Data		Well water was ft. after hours pumping gpm							
Est. Yield gpm:		Well water was ft. after hours pumping gpm							
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped X							
1 Steel 3 RMP (SR)		6 Asbestos-Cement 9 Other (specify below) Welded							
2 PVC 4 ABS		7 Fiberglass Threaded							
Blank casing dia 16 in. to 50 ft. Dia		in. to ft. Dia in. to ft.							
Casing height above land surface		in. weight 37 lbs./ft. Wall thickness or gauge No 3/4"							
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement							
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR)		11 Other (specify)							
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS		12 None used (open hole)							
Screen or Perforation Openings Are:		5 Gauzed wrapped 8 Saw cut 11 None (open hole)							
1 Continuous slot 3 Mill slot		6 Wire wrapped Transite - saw cut							
2 Louvered shutter 4 Key punched 7 Torch cut		9 Drilled holes Johnson - wire wrapped							
10 Other (specify)									
Screen-Perforation Dia 16 in. to 103 ft. Dia		in. to ft. Dia in. to ft.							
Screen-Perforated Intervals:		From 50 ft. to 60 Johnson ft. From ft. to ft.							
		From 93 ft. to 103 Transite ft. From ft. to ft.							
Gravel Pack Intervals:		From 10 ft. to 103 ft. From ft. to ft.							
		From ft. to ft. From ft. to ft.							
5 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.									
What is the nearest source of possible contamination:		10 Fuel storage 14 Abandoned water well							
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well									
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)									
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines NO APPARENT SOURCE									
Direction from well How many feet ? Water Well Disinfected? Yes X No									
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year Pump Installed? Yes No									
If Yes: Pump Manufacturer's name Model No. HP Volts									
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 8 month 10 day 1979 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236									
This Water Well Record was completed on 12 month 15 day 1979 year under the business name of Harp Well & Pump Service, Inc. by (signature) M. Arnold									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG		FROM TO		LITHOLOGIC LOG	
		0 12		Clay					
		12 17		Medium to Coarse Sand & Gravel					
		17 36		Medium Sand with Clay					
		36 42		Clay					
		42 59		Medium to Coarse Sand and Gravel					
		59 94		Clay					
		94 103		Medium to Coarse Sand and Fine Gravel					
ELEVATION:									
Depth(s) Groundwater Encountered 1. 13 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									

OFFICE USE ONLY

T

28

R

E

SEC.

15

NW ¼ SE ¼ SE ¼