

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215


28		1	W	1	6	Sw	Sw	Sw	
T		R	EW	sec	1/4	1/4	1/4	No.	

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sedgwick	Township name 	Fraction SW4-NE4	Section number 16	Town number T 28 S	Range number R 1 W
---------------------	---------------------------	-------------------	----------------------------	-----------------------------	------------------------------	------------------------------

Distance and direction from nearest town or city: **1/2 Mi. South & 1/2 Mi. W. of intersection of 39th St.**
 Street address of well location if in city: **S. & 71st W., Wichita**

3 Owner of well: **Vulcan Materials Company**
Wichita, Kansas
Well No. 10 (TH 24-72)

Locate with "X" in section below:

 Sketch map: Well No. 10

2 Type and color of material	From	To	4 Well depth: <u>123</u> ft. Date of completion <u>10/10/75</u> Well diameter <u>30-48</u> in.
Top soil	0	2	5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary
Brown clay	2	14	6 Use: ☐ Domestic ☐ Public supply ☒ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐
Med. to coarse sand & gravel	14	72	7 Casing: Material <u>Stl.</u> Height: <u>xxx</u> below Threaded ☐ Welded ☒ Surface <u>4</u> Ft. Diam. <u>16</u> in. to <u>88</u> ft. depth Weight <u>62</u> lbs./ft. in. to <u> </u> ft. depth Drive shoe? ☐ Yes ☒ No
Clay	72	90	8 Screen: Manufacturer <u>Layne</u> Type <u>St. Stl.</u> Dia. <u>16"</u> Slot/gauze <u>.105"</u> Length <u>35'</u> Set between <u>88</u> ft. and <u>123</u> ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material <u>1/8</u>
Med. to coarse sand & gravel w/some clay	90	122	9 Static water level: <u>25</u> ft. below land surface Date <u>10/6/75</u>
Blue shale	122	125	10 Pumping level below land surfaces: <u>60</u> ft. after <u>3</u> hrs. pumping <u>1000</u> g.p.m. <u>52</u> ft. after <u>1</u> hrs. pumping <u>750</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.
			11 Water sample submitted: ☒ Yes ☐ No Date <u>10/6/75</u>
			12 Well head completion: ☒ Pitless adapter ☐ Inches above grade
			13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From <u>0</u> ft. to <u>20</u> ft.
			14 Nearest source of possible contamination: ft. <u>1000</u> Direction <u>E.</u> Type <u>Creek</u> Well disinfected upon completion? ☒ Yes ☐ No
			15 Pump: ☐ Not installed Manufacturer's name <u>Layne</u> Model number <u>10</u> HP <u>50</u> Volts <u>480</u> Length of drop pipe <u>60</u> ft. capacity <u>500</u> g.p.m. Type: ☒ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other

(use a second sheet if needed)

16 Remarks: elevation **1298.6 MSL**

Topography:
☐ Hill
☐ Slope
☐ Upland
☒ Valley **Arkansas River**

17 Water well contractor's certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Layne Western Co. 102
 Business name Wichita, Kansas License No. _____
 Address _____
 Signed [Signature] Date 10/22/75
 Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5