


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NW 1/4 NW 1/4	Section number 23	Township number T 28 S R	Range number 1 W
2. Distance and direction from nearest town or city: Street address of well location if in city: 4800 South Hoover Wichita, Kansas			3. Owner of well: Jim Heimerman R.R. or street: 4800 South Hoover Road City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 1 1/2 in. Completion date Well depth 60 ft. 1-3-77
Topsoil			0	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			2	12	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine Sand			12	35	9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded GI Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. .200
Medium to coarse Sand			35	55	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauze .06 Length 15' Set between 45 ft. and 60 ft. Gravel pack? yes Size range of material 1/4-1/8"
Clay			55	60	11. Static water level: _____ mo./day/yr. 39 ft. below land surface Date 1-3-77
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.
					16. Nearest source of possible contamination: ft. 700 Direction NE Type Septic Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Flat Ground				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name _____ License No. _____ Address Wichita, Kansas Signed M. Arnold Date 5-16-77 Authorized representative
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

28
 T
 R
 23
 Sec
 1/4
 1/4
 1/4
 1/4
 NW
 NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5