

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: SEDGWICK		NW 1/4 NW 1/4 SW 1/4		35		T 28 S		R 1 W E/W	
Distance and direction from nearest town or city?				Street address of well if located within city? 6842 S. Hoover, Wichita, Ks.					
2 WATER WELL OWNER:		Jim Cunningham							
RR#, St. Address, Box # :		6842 S. Hoover							
City, State, ZIP Code :		Wichita, Ks.							
		Board of Agriculture, Division of Water Resources Application Number:							
3 DEPTH OF COMPLETED WELL		65 ft.		Bore Hole Diameter		11 in.		ft., and in. to ft.	
Well Water to be used as:		5 Public water supply		8 Air conditioning		11 Injection well			
1 Domestic		3 Feedlot		6 Oil field water supply		9 Dewatering		12 Other (Specify below)	
2 Irrigation		4 Industrial		7 Lawn and garden only		10 Observation well			
Well's static water level		2.3 ft. below land surface		measured on		8 month		2.2 day 80 year	
Pump Test Data		Well water was		ft. after		hours pumping		gpm	
Est. Yield		gpm: Well water was		ft. after		hours pumping		gpm	
4 TYPE OF BLANK CASING USED:		5 Wrought iron		8 Concrete tile		Casing Joints: Glued X Clamped			
1 Steel		3 RMP (SR)		6 Asbestos-Cement		9 Other (specify below)		Welded	
2 PVC		4 ABS		7 Fiberglass				Threaded	
Blank casing dia		5 in.		to 50 ft.		Dia in.		to ft.	
Casing height above land surface		12 in.		weight		lbs./ft.		Wall thickness or gauge No 2.00	
TYPE OF SCREEN OR PERFORATION MATERIAL:		1 Steel		3 Stainless steel		5 Fiberglass		8 RMP (SR)	
2 Brass		4 Galvanized steel		6 Concrete tile		9 ABS		12 None used (open hole)	
Screen or Perforation Openings Are:		1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut .06	
2 Louvered shutter		4 Key punched		7 Torch cut		10 Other (specify)		11 None (open hole)	
Screen-Perforation Dia		5 in.		to 65 ft.		Dia in.		to ft.	
Screen-Perforated Intervals:		From 50 ft.		to 65 ft.		From ft.		to ft.	
Gravel Pack Intervals:		From 14 ft.		to 65 ft.		From ft.		to ft.	
5 GROUT MATERIAL:		1 Neat cement		2 Cement grout		3 Bentonite		4 Other	
Grouted Intervals: From		40 ft.		to 14 ft.		From ft.		to ft.	
What is the nearest source of possible contamination:		1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage	
2 Sewer lines		5 Seepage pit		8 Feed yard		12 Insecticide storage		15 Oil well/Gas well	
3 Lateral lines		6 Pit privy		9 Livestock pens		13 Watertight sewer lines		16 Other (specify below)	
Direction from well		How many feet		?		Water Well Disinfected? Yes X No			
Was a chemical/bacteriological sample submitted to Department? Yes		No		X		If yes, date sample			
was submitted		month		day		year		Pump Installed? Yes X No	
If Yes: Pump Manufacturer's name		Fairbanks Morse		Model No. 7.5		HP 3/4		Volts 230	
Depth of Pump Intake		4.5 ft.		Pumps Capacity rated at		18 gal./min.			
Type of pump:		1 Submersible		2 Turbine		3 Jet		4 Centrifugal	
		5 Reciprocating		6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was									
completed on		8 month		22 day		80 year			
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No.		236							
This Water Well Record was completed on		12 month		4 day		1980 year			
name of Harp Well & Pump Serv., Inc.		by (signature) M. Arnold							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM		TO		LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0		2		Topsoil			
		2		18		Clay			
		18		24		Sandy Clay			
		24		37		Fine Sand			
		37		45		Fine to Medium Sand			
		45		65		Medium to Coarse Sand			
ELEVATION:									
Depth(s) Groundwater Encountered		1. 2.3 ft.		2. ft.		3. ft.		4. ft.	
								(Use a second sheet if needed)	
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									